

GBxMB AT WATSONVILLE, CA 95706

PROJECT LOCATION MAP(S)



LEGAL DESCRIPTION

SITUATE IN THE CITY OF WATSONVILLE, COUNTY OF SANTA CRUZ, STATE OF CALIFORNIA AND

BEGINNING AT A POINT ON THE NORTHWESTERN BOUNDARY OF THE LANDS

BEING A PORTION OF THE LANDS CONVEYED TO OW FAMILY-OHLONE PARKWAY, LLC A CALIFORNIA LIMITED LIABILITY COMPANY, BY GRANT DEED RECORDED OCTOBER 13 2015 AT 11:28 AM IN DOCUMENT NO. 2015-0041365 OFFICIAL RECORDS OF SANTA CRUZ COUNTY, MORE PARTICULARLY DESCRIBED AS FOLLOWS:

CONVEYED TO THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION BY QUITCLAIM DEED RECORDED OCTOBER 12, 2012 AT 8:36 AM IN DOCUMENT NO. 2012-0050154 OFFICIAL RECORDS OF SANTA CRUZ COUNTY FROM WHICH THE INTERSECTION OF SAID NORTHWESTERN BOUNDARY WITH THE EASTERN BOUNDARY OF CALIFORNIA STATE HIGHWAY ROUTE NO. 1 AS SHOWN ON THAT CERTAIN MAP ENTITLED "RECORD OF SURVEY - MANABE WETLANDS RESTORATION PROJECT" FILED FOR RECORD MAY 22, 2015 IN VOLUME 123 OF MAPS, PAGE 21, SANTA CRUZ COUNTY RECORDS BEARS SOUTH 51° 10' 29" WEST 455.11 FEET DISTANT; THENCE FROM SAID POINT OF BEGINNING AND LEAVING SAID NORTHWESTERN BOUNDARY OF THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION NORTH 29° 28' 42" WEST 766.89 FEET TO THE SOUTHERN BOUNDARY OF MANABE OW ROAD, A CITY STREET 78 FEET WIDE, AS CONVEYED TO THE CITY OF WATSONVILLE, A MUNICIPAL CORPORATION BY GRANT DEED RECORDED SEPTEMBER 1, 2016 AT 7:47 AM IN

DOCUMENT NO. 2016- 0032795 OFFICIAL RECORDS OF SANTA CRUZ COUNTY; THENCE ALONG SAID SOUTHERN BOUNDARY THEREOF SOUTH 53° 27' 55" WEST 90.14 FEET TO A POINT OF CURVATURE; THENCE ALONG A TANGENT CURVE TO THE LEFT WITH A RADIUS OF 31.00 FEET, THROUGH A CENTRAL ANGLE OF 26° 55' 45" AND AN ARC LENGTH OF 14.57 FEET TO A POINT OF REVERSE CURVATURE; THENCE ALONG A TANGENT CURVE TO THE RIGHT WITH A RADIUS OF 52.00 FEET, THROUGH A CENTRAL ANGLE OF 152° 53' 17" AND AN ARC LENGTH OF 138.76 FEET TO THE END OF SAID

36' 52" WEST 4.47 FEET TO THE SOUTHERN BOUNDARY OF THE LANDS CONVEYED TO THE CITY OF WATSONVILLE, A MUNICIPAL CORPORATION, BY GRANT DEED RECORDED JANUARY 30, 2012 AT 8:07 AM IN DOCUMENT NO. 2012-0004808 OFFICIAL RECORDS OF SANTA CRUZ COUNTY; THENCE LEAVING SAID MANABE OW ROAD AND ALONG THE LAST SAID SOUTHERN BOUNDARY CONVEYED TO THE CITY OF WATSONVILLE THEREOF SOUTH 53° 27' 55" WEST 268.38 FEET TO THE INTERSECTION WITH THE AFOREMENTIONED EASTERN BOUNDARY OF CALIFORNIA STATE HIGHWAY ROUTE NO. I; THENCE LEAVING THE LANDS OF THE CITY OF WATSONVILLE AND ALONG SAID EASTERN BOUNDARY THEREOF SOUTH 29° 28' 42" EAST 808.19 FEET AND SOUTH 24° 48' 19" EAST 56.38 FEET TO THE HEREINABOVE SAID NORTHWESTERN BOUNDARY OF THE LANDS CONVEYED TO THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION; THENCE LEAVING CALIFORNIA STATE HIGHWAY ROUTE NO. 1 AND ALONG SAID NORTHWESTERN BOUNDARY THEREOF NORTH 51° 10' 29" EAST 455.11 FEET TO THE POINT OF BEGINNING OF THIS DESCRIPTION.

THIS LEGAL DESCRIPTION IS MADE PURSUANT TO THAT CERTAIN CERTIFICATE OF COMPLIANCE RECORDED JULY 24, 2018, AS INSTRUMENT NO. 2018-022647 OF OFFICIAL PARCEL 2:

SITUATE IN THE CITY OF WATSONVILLE, COUNTY OF SANTA CRUZ, STATE OF

BEING A PORTION OF THE LANDS CONVEYED TO OW FAMILY-OHLONE PARKWAY. LLC A CALIFORNIA LIMITED LIABILITY COMPANY, BY GRANT DEED RECORDED OCTOBER 13, 2015 AT 11:28 AM IN DOCUMENT NO. 2015-0041365 OFFICIAL RECORDS OF SANTA CRUZ COUNTY, MORE PARTICULARLY DESCRIBED AS FOLLOWS:

BEGINNING AT A POINT ON THE NORTHWESTERN BOUNDARY OF THE LANDS CONVEYED TO THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION BY QUITCLAIM DEED RECORDED OCTOBER 12, 2012 AT 8:36 AM IN DOCUMENT NO. 2012-0050154 OFFICIAL RECORDS OF SANTA CRUZ COUNTY FROM WHICH THE INTERSECTION OF SAID NORTHWESTERN BOUNDARY WITH THE EASTERN BOUNDARY OF CALIFORNIA STATE HIGHWAY ROUTE NO. 1 AS SHOWN ON THAT CERTAIN MAP ENTITLED "RECORD OF SURVEY - MANABE WETLANDS RESTORATION PROJECT" FILED FOR RECORD MAY 22, 2015 IN VOLUME 123 OF MAPS, PAGE 21, SANTA CRUZ COUNTY RECORDS BEARS SOUTH 51° 10' 29" WEST 925.48 FEET DISTANT; THENCE FROM SAID POINT OF BEGINNING AND LEAVING SAID NORTHWESTERN BOUNDARY OF THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION NORTH 21° 38' 53" WEST 641.87 FEET TO THE SOUTHERN BOUNDARY OF MANABE OW ROAD, A CITY STREET 78 FEET WIDE, AS CONVEYED TO THE CITY OF WATSONVILLE, A MUNICIPAL

CORPORATION BY GRANT DEED RECORDED SEPTEMBER 1, 2016 AT 7:47 AM IN DOCUMENT NO. 2016- 0032795 OFFICIAL RECORDS OF SANTA CRUZ COUNTY; THENCE ALONG SAID SOUTHERN BOUNDARY THEREOF SOUTH 68° 21' 07" WEST 392.77 FEET TO A POINT OF CURVATURE; THENCE ALONG A TANGENT CURVE TO THE LEFT WITH A RADIUS OF 627.00 FEET, THROUGH A CENTRAL ANGLE OF 14° 53' 18" AND AN ARC LENGTH OF 162.93 FEET TO THE END OF SAID CURVE; THENCE LEAVING SAID MANABE OW ROAD SOUTH 29° 28' 42" EAST 766.89 FEET TO THE INTERSECTION WITH THE HEREINABOVE DESCRIBED NORTHWESTERN BOUNDARY OF THE LANDS CONVEYED TO THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION: THENCE ALONG SAID NORTHWESTERN BOUNDARY THEREOF NORTH 51° 10' 29" EAST 470.37 FEET TO THE POINT OF BEGINNING OF THIS DESCRIPTION.

THIS LEGAL DESCRIPTION IS MADE PURSUANT TO THAT CERTAIN CERTIFICATE OF COMPLIANCE RECORDED JULY 24, 2018, AS INSTRUMENT NO. 2018-022648 OF

PARCEL 3:

SITUATE IN THE CITY OF WATSONVILLE, COUNTY OF SANTA CRUZ, STATE OF CALIFORNIA AND

> BEING A PORTION OF THE LANDS CONVEYED TO OW FAMILY-OHLONE PARKWAY, LLC A CALIFORNIA LIMITED LIABILITY COMPANY, BY GRANT DEED RECORDED OCTOBER 1

2015 AT 11:28 AM IN DOCUMENT NO. HYPERLINK "https://docs.clarityfirst.com/meta/index? m=ff1877e0-016d-4b55-bc91a8998e85a21a&q=q7WmzVDH640n1ptZiJogyYeyptH4GTjjaHRy9FkwhuuKqo%3d&h 9b9e526b-1058-47ef-90d4-a4e10995cff1"2015-0041365 OFFICIAL RECORDS OF SANTA CRUZ COUNTY, MORE PARTICULARLY DESCRIBED AS FOLLOWS:

BEGINNING AT A POINT ON THE NORTHWESTERN BOUNDARY OF THE LANDS CONVEYED TO THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION BY QUITCLAIM DEED RECORDED OCTOBER 12, 2012 AT 8:36 AM IN DOCUMENT NO. HYPERLINK "https://docs.clarityfirst.com/meta/index?m=ff1877e0-016d-4b55-bc91a8998e85a21a&q=q7WmzVDH640n1ptZiJogyXtvlAWUrdlWNfpCcfvbJL0%3d&h= 90327197-b699-4a7f-9edc-c72eb77b9565"2012-0050154 OFFICIAL RECORDS OF SANTA CRUZ COUNTY FROM WHICH THE INTERSECTION OF SAID NORTHWESTERN

BOUNDARY WITH THE EASTERN BOUNDARY OF CALIFORNIA STATE HIGHWAY ROUTE NO. 1 AS SHOWN ON THAT CERTAIN MAP ENTITLED "RECORD OF SURVEY - MANABE WETLANDS RESTORATION PROJECT" FILED FOR RECORD MAY 22, 2015 IN HYPERLINK "https://docs.clarityfirst.com/meta/index?m=ff1877e0-016d-4b55-bc91a8998e85a21a&q=q7WmzVDH640n1ptZiJogybiCj38y6qeajouFPRIZ3XE%3d&h= 428b5998-34c7-422e-837a-416ad648abf7"VOLUME 123 OF MAPS, PAGE 21, SANTA CRUZ COUNTY RECORDS BEARS SOUTH 51° 10' 29" WEST 925.48 FEET DISTANT: THENCE

FROM SAID POINT OF BEGINNING AND LEAVING SAID NORTHWESTERN BOUNDARY OF THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION NORTH 21° 38' 53" WEST 641.87 FEET TO THE SOUTHERN BOUNDARY OF MANABE OW ROAD, A CITY STREET 78 FEET WIDE, AS CONVEYED TO THE CITY OF WATSONVILLE, A MUNICIPAL CORPORATION BY GRANT DEED RECORDED SEPTEMBER 1, 2016 AT 7:47 AM IN DOCUMENT NO. HYPERLINK "https://docs.clarityfirst.com/meta/index?m=ff1877e0-016d-4b55bc91-a8998e85a21a&q=q7WmzVDH640n1ptZiJogydpT8uccyptvd0SrE7lk2RDLfk% 3d&h=d513f7a6-b843-4a54-ab5b-f8e2ddd87c04"2016- HYPERLINK

"https://docs.clarityfirst.com/meta/index?m=ff1877e0-016d-4b55-bc91a8998e85a21a&q=q7WmzVDH640n1ptZiJogydpT8uccyptvd0SrE7lk2RDLfk% 3d&:h=d513f7a6-b843-4a54-ab5b-f8e2ddd87c04"0032795 OFFICIAL RECORDS OF SANTA CRUZ COUNTY; THENCE ALONG SAID SOUTHERN BOUNDARY THEREOF NORTH 68° 21' 07" EAST 632.96 FEET TO A POINT OF CURVATURE; THENCE ALONG A NON-TANGENT CURVE TO THE RIGHT WITH A RADIAL BEARING OF SOUTH 12° 47' 23" EAST, A RADIUS OF

55.50 FEET, THROUGH A CENTRAL ANGLE OF 37° 09' 23" AND AN ARC LENGTH OF 35.99 FEET TO THE END OF SAID CURVE; THENCE LEAVING SAID CURVE SOUTH 65° 38' 00" EAST 5.34 TO THE WESTERN BOUNDARY OF OHLONE PARKWAY, A CITY STREET 110 FEET WIDE) AS SHOWN ON THE ABOVE SAID RECORD OF SURVEY MAP; THENCE LEAVING MANABE OW ROAD AND ALONG SAID WESTERN BOUNDARY OF OHLONE PARKWAY SOUTH 22° 12' 23" EAST 414.00 FEET TO THE INTERSECTION WITH THE HEREINABOVE DESCRIBED NORTHWESTERN BOUNDARY OF THE LANDS CONVEYED TO THE SANTA CRUZ COUNTY REGIONAL TRANSPORTATION COMMISSION; THENCE ALONG SAID NORTHWESTERN BOUNDARY THEREOF SOUTH 51° 10' 29" WEST 703.47 FEET TO THE POINT OF BEGINNING OF THIS DESCRIPTION.

THIS LEGAL DESCRIPTION IS MADE PURSUANT TO THAT CERTAIN CERTIFICATE OF COMPLIANCE RECORDED JULY 24, 2018, AS INSTRUMENT NO. 2018-022649 OF OFFICIAL

PROJECT TEAM

ARCHITECT OF RECORD

RYAN A+E, INC. 4275 EXECUTIVE SQUARE, SUITE 370 LA JOLLA, CA

PHONE: (858) 812-7910 LORI JOHNSON Lori.Johnson@RyanCompanies.com

CIVIL ENGINEER

BOWMAN & WILLIAMS CIVIL ENGINEERS AND LAND SURVEYORS 3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073 PHONE: (831) 426-3560 JOEL RICCA

Joel@bowmanandwilliams.com

LANDSCAPE ARCHITECT

SSA LANDSCAPE ARCHITECTS, INC. 303 POTRERO ST., SUITE 40-C SANTA CRUZ, CA 95060 PHONE: (831) 459-0455 CHRISTIAN HARRIS christian@ssala.com

ELECTRICAL

jj@kraemereng.com

KRAEMER CONSULTING ENGINEERS, P.L.L.C. 2050 WEST WHISPERING WIND DR., SUITE 158 PHOENIX, AZ 85085 PHONE: (602) 285-1669 JAMES JONES, JR.

LONE OAK-WATSONVILLE, L.L.C 6250 NORTH RIVER ROAD ROSEMONT, IL 60018 (847) 430-9766 PEHR PETERSON

PAPeterson@reyesholdings.com

DESIGN/BUILDER

RYAN COMPANIES US. INC. 4275 EXECUTIVE SQUARE, SUITE 370 LA JOLLA, CA PHONE: (858) 812-7910 MICHAEL BEADLE Michael.Beadle@RyanCompanies.com

PROJECT MANAGER

RYAN COMPANIES US, INC. 533 SOUTH THIRD STREET, SUITE 100 MINNEAPOLIS, MN 55415 PHONE: (612) 492-4679 MARK SHEFCHIK Mark.Shefchik@RyanCompanies.com

ASSESSOR'S PARCEL NUMBER:

LEGAL DESCRIPTION:

CURRENT LAND USE:

PROPOSED LAND USE:

LANDSCAPE AREA:

SITE SUMMARY:

ZONING:

DETENTION AREA: +/- 40,209 SQ.FT. (@ 8.5%) **DRIVE AISLE AREA:** +/- 226,474 SQ.FT. HARDSCAPE AREA: +/- 207,776 SQ.FT.

PROJECT INFORMATION

BE PLACED AROUND THE TRUCK COURT

018-711-33

FACILITY. THE BUILDING IS ±155,847 SF. THERE WILL BE A ±7,950 SF

REFER TO TITLE SHEET

± 11.5 AC OF THE TOTAL SITE WILL BE DEVELOPED FOR A NEW DISTRIBUTION

MEZZANINE FOR THE OFFICE. NEW LANDSCAPING, NEW PARKING, NEW SITE LIGHTING, NEW STORM WATER DETENTION. 9' TALL SECURITY FENCING WIL

106,325 SQ.FT.

MANABE OW SPECIFIC PLAN IL -INDUSTRIAL

VACANT COMMERCIAL LAND LOCATED IN

IS DESIGNATED AS BUSINESS PARK WITH

106.325 SQ.FT. / 502.319 SQ.FT = 21%

+/- 502,319 SQ.FT. (11.5 ACRES)

THE MANABE OW SPECIFIC PLAN AREA. SITE

INDUSTRIAL USE WAREHOUSE AND DISTRIBUTION

FAR CALCULATION:

BUILDING FOOTPRINT: +/- 147,380 SQ.FT. (@25.8%) **MEZZANINE:** +/- 8,467 SQ.FT. TOTAL BUILDING AREA: +/- 155,847 SQ.FT. FAR = G/B

FAR = .32

BUILDING SUMMARY:

BUILDING TYPE: TYPE IIIB FULLY SPRINKLERED ESFR BUILDING OCCUPANCY: PRIMARY S-2 ACCESSORY S-1, B, A **UNLIMITED BUILDING AREA PER CBC 507**

PARKING SUMMARY:

AUTO STALLS REQUIRED:

CLEAN AIR/VANPOOL/EV STALLS:

GROSS SITE AREA:

0 TO 20,000 SQUARE FEET FLOOR AREA, 1 SPACE FOR EACH 300 SF FLOOR AREA, PLUS 1 SPACE FOR EACH 500 SF FLOOR AREA IN EXCESS OF 20,000 SQUARE FEET = 53 STALLS

FAR = 502,319 / 155,847

WAREHOUSE:

5 SPACES, PLUS 1 SPACE FOR EACH EMPLOYEE ON THE SHIFT WITH THE MAXIMUM NUMBER OF PERSONNEL = 40 STALLS

TOTAL REQUIRED = 93 STALLS

REQUIRED: 12 PROVIDED: 12

TRUCK DOCKS PROVIDED:	20 STALLS
TRAILER STALL PROVIDED:	33 TRAILERS
TRAILER BAY:	2 STALLS
GRADE DOORS:	6
AUTO STALLS PROVIDED:	93 STALLS @ .7/1000
BICYCLE STALLS PROVIDED: RACKS	REQUIRED: 9 PROVIDED: 10
LONG TERM LOCKERS	REQUIRED: 9 PROVIDED: 10
ADA STALLS:	REQUIRED: 7 PROVIDED: 8
EV STALLS:	REQUIRED: 9 PROVIDED: 9

RYAN A+E, INC. **4275 Executive Square, Suite 370** La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

CONSULTANTS







PROJECT INFORMATION

Lone Oak-Watsonville,

WATSONVILLE, CA 95076

© 2022 RYAN A+E, INC.

DRAWN BY	CHECKED BY
Author	Checker
JOB NO.	DATE
701-048	2022-07-21

07-27-21 DESIGN REVIEW SUBMITTAL 2 09-30-21 DESIGN REVIEW RESUBMITTAL


3 01-14-22 DESIGN REVIEW RESUBMITTAL 4 04-18-22 DESIGN REVIEW RESUBMITTAL 5 07-15-22 DESIGN REVIEW RESUBMITTAL

DESIGN REVIEW RESUBMITTAL

TITLE SHEET

2022.07.15

Attachment 1 Page 1 of 44




PROJECT INF	<u>OR</u>	MATION	,		
ASSESSOR'S PARCEL NUMBER:	018-71	11-33			
ZONING:	MANA	ABE OW SPECIFIC PLAN IL	INDUSTRIAL		
LEGAL DESCRIPTION:	REFE	R TO TITLE SHEET		RYAN A+E, IN	
PROJECT DESCRIPTION: ± 11.5 AC OF THE TOTAL SITE FACILITY. THE BUILDING IS ±1 MEZZANINE FOR THE OFFICE. LIGHTING, NEW STORM WATE WILL BE PLACED AROUND TH	155,847 E. NEW ER DE	17 SF. THERE WILL BE A ± W LANDSCAPING, NEW PA ETENTION. 9'-0" TALL SECU	£7,950 SF ARKING, NEW SITE	La Jolla, CA 9 858-812-7910 858-812-7930) tel) fax
	THE N	ANT COMMERCIAL LAND L MANABE OW SPECIFIC PLA SIGNATED AS BUSINESS I STRIAL USE.	AN AREA. SITE	WWW.RYANC OWNER	COMPANIES.COM
PROPOSED LAND USE:	INDUS	STRIAL USE WAREHOUSE	AND DISTRIBUTION	1	
ANDSCAPE AREA:	106,32	25 SQ.FT.			
	106,32	25 SQ.FT. / 502,319 SQ.FT	= 21%]	
SITE SUMMARY:				1	
		2,319 SQ.FT. (11.5 ACRES)	<u>·)</u>		
DETENTION AREA:	+/- 40,	,209 SQ.FT. (@ 8.5%)		CONSULTANTS	
DRIVE AISLE AREA:	+/- 226	6,474 SQ.FT.		The second second	<u>iii</u>
HARDSCAPE AREA:	+/- 207	7,776 SQ.FT.		CCA	A
				33/	E
AR CALCULATION:				LANDSCAPE ARCHITEC	
BUILDING FOOTPRINT:	+/- 147	7,380 SQ.FT. (@25.8%)		creating better place	es
MEZZANINE:	+/- 8,4	467 SQ.FT.		DW BOW	
TOTAL BUILDING AREA:	+/- 15!	5,847 SQ.FT.		PM CONSULTING	MAN & WILLIAM G CIVIL ENGINEERS & LAND SURVEYO
<u> </u>	FAR =	= G/B			
,	FAR =	= 502,319 / 155,847	!	Krae!	mer Consulting Engineers, PLLC.
	FAR =		!	Mecha 2050 We Phoenix	nanical and Electrical Engineers Vest Whispering Wind Dr., Suite 158 x. Arizona 85085-2864
UILDING SUMMARY:	-			(602) 288 (602) 28 JOB #	x, Arizona 85085-2864 88-1669 85-9450 - fax
BUILDING TYPE: TYPE IIIB FUL				1	
BUILDING OCCUPANCY: PRIM			A		
UNLIMITED BUILDING AREA P	ER CE	BC 507		PROJECT INFORM	ATION
PARKING SUMMARY:				Lone	
AUTO STALLS REQUIRED:			!	Oak-Wa	atsonville,
		LOOR AREA, 1 SPACE FOR			atoonvine,
	SPACE	FOR EACH 500 SF FLOOF		L.L.C.	
WAREHOUSE:					
5 SPACES, PLUS 1 SPAC	R OF P	OR EACH EMPLOYEE ON T PERSONNEL = 40 S TOTAL REQUIRED = 93 S	STALLS	WATSON	/ILLE, CA 95076
		·		-	
TRUCK DOCKS PROVIDED:			0 STALLS	-	
TRAILER STALL PROVIDED:			3 TRAILERS	_	
TRAILER BAY:			STALLS	_	
GRADE DOORS:		6		_	
AUTO STALLS PROVIDED:		DECUIDED: 0	3 STALLS @ .7/1000	-	
BICYCLE STALLS PROVIDED:	RACK			-	
LONG TERM LOCKERS		REQUIRED: 9		-	
ADA STALLS:			PROVIDED: 8	_	
EV STALLS:			PROVIDED: 9	_	
CLEAN AIR/VANPOOL/EV STA	LLS:	REQUIRED: 17	12 PROVIDED: 12		
MPLOYEE SCHEDULE:				© 2022 RYAN A+E	i, INC.
DELIVERY - GROUP A	8	MONDAY THRU FRIDAY	4:00AM TO 1:00PM	DRAWN BY	CHECKED BY Checker
DELIVERY - GROUP B	8	MONDAY THRU FRIDAY	5:30AM TO 2:30PM	Author JOB NO.	Checker DATE
DELIVERY - GROUP C	8	MONDAY THRU FRIDAY	7:00AM TO 4:00PM	JOB NO. 701-048	DATE 2022-07-21
WAREHOUSE - DAY	6	MONDAY THRU FRIDAY	5:00AM TO 2:00PM		
WAREHOUSE - SWING	3	MONDAY THRU FRIDAY	11:00AM TO 8:00PM		
WAREHOUSE - NIGHT	15	SUNDAY THRU	6:00PM TO 4:00AM	-	
	<u> </u>	THURSDAY		1 07-27-21	DESIGN REVIEW SUBMITT
SALES	25	N/A	N/A		DESIGN REVIEW RESUBM
ADMIN	2	MONDAY THRU FRIDAY	8:00AM TO 5:00PM	4 04-18-22	DESIGN REVIEW RESUBM DESIGN REVIEW RESUBM
GENERAL NOTES: 1. ALL GATES WILL REQUIRE THE INSTALLATION OF 2. EMERGENCY RESPONDER RADIO COVERAGE SY					DESIGN REVIEW RESUBM
ALL FIRE HYDRANTS WILL BE PRIVATE HYDRANT.			RED AND MAINTAINED		N REVIEW

- IN ACCORDANCE WITH NFPA 20 & 24.
- 4. CLASS I STANDPIPES SHALL BE INSTALLED.
- 5. NO TRUCK WASHING WILL BE PERFORMED ON SITE, NO SEWER ALLOWED IN TRUCK AREA.


RESUBMITTAL 2022.07.15

SITE PLAN

AS-1



1"=30' | | |




121534 SF | 100 | 1215 |

В


RECEIVING OFFICE


250 SCRUBBER

Attachment 1 Page 3 of 44



0 15 30





INDICATES EGRESS

INDICATES EGRESS EXIT

© 2022 RYAN A+E, INC.

L.L.C.

DRAWN BY **CHECKED BY** Checker **DATE** 2022-07-15 JOB NO. 701-048


WATSONVILLE, CA 95076

1 07-27-21 DESIGN REVIEW SUBMITTAL 2 09-30-21 DESIGN REVIEW RESUBMITTAL 3 01-14-22 DESIGN REVIEW RESUBMITTAL

DESIGN REVIEW RESUBMITTAL 2022.07.15


MEZZANINE PLAN

Attachment 1 Page 4 of 44



DESIGN REVIEW - LEVEL 1 ENLARGED PLAN 1 1/16" = 1'-0" A-3





0 8' 16'

64

OCCUPANCY OCCUPANCY BUSINESS AREAS (B) ASSEMBLY (A-2)(A-3) NO FIXED SEATING - CONCENTRATED (CHAIRS) 7 NET 5 NET - STANDING SPACE 15 NET - UNCONCENTRATED ASSEMBLY (A-5) NO FIXED SEATING 15 NET STORAGE (ACCESSORY) (S-1) STORAGE (S-2) 500 GROSS N.O. CIRCULATION

VERTICAL CIRCULATION

FLOOR AREA 150 GROSS RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax WWW.RYANCOMPANIES.COM 500 GROSS

CONSULTANTS

N.O.







PROJECT INFORMATION

Lone Oak-Watsonville,

WATSONVILLE, CA 95076


© 2022 RYAN A+E, INC.

DRAWN BY **CHECKED BY** Checker JOB NO. DATE 2022-07-15

1 07-27-21 DESIGN REVIEW SUBMITTAL 2 09-30-21 DESIGN REVIEW RESUBMITTAL 3 01-14-22 DESIGN REVIEW RESUBMITTAL

DESIGN REVIEW RESUBMITTAL 2022.07.15

ENLARGED FLOOR PLANS



GENERAL NOTES

- REFER TO STRUCTURAL DRAWINGS FOR SLAB
 ON GRADE CONSTRUCTION, CONTROL AND
 ISOLATION JOINTS
- ISOLATION JOINTS.

 2. COORDINATE UNDERGROUND AND UNDER SLAB UTILITIES WITH RELEVANT TRADES PRIOR TO SLAB POUR. COORDINATE ALL SLEEVES THROUGH/UNDER FOOTING AND FOUNDATION W/ STRUCTURAL ENGINEER.
- 3. ALL WALLS TO ROOF DECK TO BE CONSTRUCTED TO ACCOMMODATE DEFLECTION OF ROOF STRUCTURE.
- 4. REFER TO STRUCTURAL ENGINEERING DRAWINGS FOR ADDITIONAL INFORMATION PERTAINING TO STRUCTURAL COMPONENT SIZES, LOCATIONS, CONFIGURATIONS, AND CAPACITIES.
- STAIR SUPPLIER SHALL BE RESONSIBLE FOR CODE COMPLIANCE AND STRUCTURAL INTEGRITY FOR ALL MATERIALS FURNISHED.
- PROVIDE FIRE EXTINGUISHERS OF SIZE AND TYPE AND LOCATION AS REQUIRED BY THE FIRE MARSHALL.
 ROOFING SYSTEM TO BE 60-MIL TPO MECHANICALLY FASTENED ROOFING SYSTEM OVER 1/2" RETRO-FIT BOARD AND 2 LAYERS OF
- 2¹/₂" POLY ISO INSULATION (R-30).
 8. ALL EQUIPMENT SHOWN FOR REFERENCE ONLY REFER TO MECHANICAL AND ELECTRICAL DRAWINGS FOR EXACT EQUIPMENT, SIZE AND

DIMENSIONS:

LOCATION.

OTHERWISE.

- 1. SUBCONTRACTOR TO VERIFY DIMENSIONS AND CONDITIONS SHOWN ON THESE DRAWINGS ANY OMISSIONS, DISCREPANCIES, OR CONFLICTS MUST BE REPORTED TO THE DESIGN BUILD IMMEDIATELY.
- DIMENSIONS ARE AT 3'-0" ABOVE FINISHED FLOOR AND FROM FACE OF FINISHED PARTITION UNLESS NOTED OTHERWISE.
 DRAWINGS SHOULD NOT BE SCALED DIMENSIONS GOVERN. LARGE SCALE
- DRAWINGS GOVERN OVER SMALL SCALE DRAWINGS.

 4. DIMENSIONS AT EXTERIOR WALLS ARE TAKEN TO EXTERIOR FACE OF CONCRETE WALL OR TO EXTERIOR SIDE OF SHEATHING UNLESS NOTED
- DIMENSIONS AT INTERIOR WALLS ARE TAKEN TO FACE OF GYP UNLESS NOTED OTHERWISE.

TY/AN

RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

OWNE

CONSULTANTS







PROJECT INFORMATION

Lone Oak-Watsonville, L.L.C.

WATSONVILLE, CA 95076

ROOF PLAN KEYNOTES

- 1 SINGLE PLY ROOF WITH REFLECTIVE MEMBRANE
- 2 4'-0" x 8'-0" SKYLIGHT
- 3 PRIMARY ROOF DRAIN
- 4 SECONDARY ROOF DRAIN
- (5) TAPERED INSULATION CRICKET
- 6 MECHANICAL UNIT
- 7 APPX LOCATION OF FUTURE SOLAR PANELS
 ADDITIONAL NOTES PER ROOF PLAN

© 2022 RYAN A+E, INC.

DRAWN BY
Author
Checker

JOB NO.
701-048

CHECKED BY
Checker

DATE
2022-07-15

07-27-21 DESIGN REVIEW SUBMITTAL
 09-30-21 DESIGN REVIEW RESUBMITTAL
 01-14-22 DESIGN REVIEW RESUBMITTAL

DESIGN REVIEW RESUBMITTAL

ROOF PLAN


2022.07.15

A-4





Attachment 1 Page 8 of 44



Attachment 1 Page 9 of 44









NORTH BUILDING PERPECTIVE 3
A-8



RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

0

CONSULTANTS







PROJECT INFORMATION

Lone Oak-Watsonville, L.L.C.

WATSONVILLE, CA 95076

© 2022 RYAN A+E, INC.

DRAWN BY
Author
Checker

JOB NO.
701-048

CHECKED BY
Checker


DATE
2022-07-15

2 09-30-21 DESIGN REVIEW RESUBMITTAL 3 01-14-22 DESIGN REVIEW RESUBMITTAL

DESIGN REVIEW
RESUBMITTAL
2022.07.15

BUILDING 3D VIEWS

A-8



40.0 SQFT

FABRICATE (1) NON-ILLUMINATED WALL SIGN. .080 ALUMINUM FACE WITH 2" RETURNS. RAIL-MOUNTED FLUSH WITH WALL SURFACE. PRINTED VINYL GRAPHICS. RETURNS PAINTED BLACK.

MOUNTED ON TOP OF NORTH AND SOUTH ELEVATION PANEL, CENTERED VERTICALLY AT BETWEEN CONCRETE PANEL JOINTS.



EXAMPLE SIGNAGE FOR REFERENCE ON EXISTING BUILDING






30.0 SQFT

FABRICATE (1) DOUBLE-FACED NON-ILLUMINATED MONUMENT SIGN.
.080 ALUMINUM FACE WITH 2" RETURNS.
STUD MOUNTED TO EXISTING MONUMENT.
PRINTED VINYL GRAPHICS.
RETURNS PAINTED BLACK.



EXAMPLE MONUMENT SIGNAGE FOR REFERENCE ON AN EXISTING BUILDING



.4 SQFT

FABRICATE (1) SET OF ADDRESS NUMBERS. .5" ACRYLIC PAINTED SATIN BLACK. STUD MOUNTED TO EXISTING MONUMENT ON STREET SIDE.

MONUMENT SIGNAGE 2 1" = 1'-0" A-9 RYAN

RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

01

CONSULTANTS







PROJECT INFORMATION

Lone
Oak-Watsonville,
L.L.C.

WATSONVILLE, CA 95076

© 2022 RYAN A+E, INC.

DRAWN BY
Author
Checker

JOB NO.
701-048

CHECKED BY
Checker

DATE
2022-07-15

2 09-30-21 DESIGN REVIEW RESUBMITTAL 3 01-14-22 DESIGN REVIEW RESUBMITTAL


DESIGN REVIEW
RESUBMITTAL
2022.07.15

EXAMPLE SIGNAGE

A-9

GBXMB WATSONVILLE

200 MANABE OW ROAD, WATSONVILLE, CALIFORNIA



THE INTENT OF THESE IMPROVEMENT PLANS IS TO SHOW:

- THE DESIGN FOR REVIEW BY THE CITY OF WATSONVILLE
- 2. TO ACCOMPANY PLANS BY RYAN COMPANIES

NOTES ON TOPOGRAPHIC INFORMATION

- 1. ALL SURVEY INFORMATION HAS BEEN PROVIDED BY MID COAST ENGINEERS, CIVIL ENGINEERS AND LAND SURVEYORS, WATSONVILLE CA, (831) 724-2580. THEIR JOB NO. 20143Z3, DATED 12/30/20.
- 2. THE TOPOGRAPHIC BASE MAP WAS FROM AN AERIAL SURVEY. PRIOR TO FINAL DESIGN THE EXISTING UTILITY AND SITE IMPROVEMENT CONFORMS SHOULD BE SURVEYED TO CONFIRM A HIGHER LEVEL OF ACCURACY.
- 3. THE LOCATIONS OF EXISTING UTILITIES AS SHOWN ON THE PLANS WERE OBTAINED FROM UTILITY COMPANIES AND MAY NOT REPRESENT TRUE LOCATION. IT IS THE CONTRACTOR'S RESPONSIBILITY TO VERIFY THE LOCATION AND DEPTH OF THESE UTILITIES PRIOR TO CONSTRUCTION, AND TO NOTIFY THE PROJECT ENGINEER IN CASE OF CONFLICT.
- 4. CALL U.S.A. (UNDERGROUND SERVICE ALERT) (800) 642-2444 BEFORE ANY EXCAVATION.

LEGEND ABBREVIATIONS ASPHALT CONCRETE ANGLE POINT FINISH GRADE SPOT ELEVATION BEGIN CURVE BACK OF WALK BOTTOM OF STEP (P) CATCH BASIN BUSINESS PARK ROAD NORTH BUSINESS PARK ROAD SOUTH (P) CONC PAVEMENT CATCH BASIN CENTERLINE CITY OF WATSONVILLE (P) FIRE LANE ASPHALT PAVEMENT DOWNSPOUT END CURVE **ELEVATION** EXISTING (P) ASPHALT PAVEMENT FIRE DEPARTMENT FINISHED GRADE (P) LANDSCAPED AREAS FIRE SERVICE FACE OF WALL (P) BIO-RETENTION AREAS (P) CONTOUR MAXIMUM PROPOSED (P) PERFORATED PIP PERFORATED PAVEMENT (E) SEWER (P) SEWER SANTA CRUZ WATER DEPARTMENT STORM DRAIN CLEANOUT (E) ELECTRICA IRRIGATION SLEEVE SANITARY SEWER CLEANOUT (E) GAS SLOUGH ROAD WEST S.R.W. TOP OF CURB (E) WATER LINE TOP OF GRAVEL TOP OF PAVEMENT TOP OF STEP (P) WATER LINE UNLESS NOTED OTHERWISE

SHEET INDEX

C0.0	COVER SHEET
C1.0	EXISTING CONDITIONS MAP — BOUNDARIES AND EASEMENTS
C1.1	EXISTING CONDITIONS MAP - TOPOGRAPHY
C1.2	PRELIMINARY DEMOLITION PLAN
C2.0	OVERALL PRELIMINARY SITE PLAN
C2.1	PRELIMINARY SITE PLAN
C2.2	OFFSITE IMPROVEMENT PLAN & PROFILE
C2.3	STORM DRAIN & WATER LINE EASEMENT PLAN
C2.4	OFFSITE STRIPING PLAN
C3.0	OVERALL PRELIMINARY GRADING PLAN
C3.1	PRELIMINARY GRADING PLAN
C3.2	PRELIMINARY CROSS SECTIONS
C3.3	PRELIMINARY CROSS SECTIONS
C3.4	PRELIMINARY RETAINING WALL PROFILES
C3.5	GEOTECHNICAL RECOMMENDATIONS
C4.0	PRELIMINARY DRAINAGE PLAN
C4.1	PRELIMINARY DRAINAGE PLAN
C5.0	PRELIMINARY UTILITY PLAN
C6.0	PHASE 1 PRELIMINARY STORMWATER POLLUTION PREVENTION PLAN
C6.1	PHASE 2 PRELIMINARY STORMWATER POLLUTION PREVENTION PLAN
C6.2	PHASE 1 PRELIMINARY SEDIMENT TRAPS SIZING & DETAILS
C6.3	PRELIMINARY EROSION CONTROL DETAILS
C7.1	STANDARD DETAILS
C7.2	STANDARD DETAILS
C7.3	STANDARD LID DETAILS
	STANDARD LID DETAILS
	STANDARD LID DETAILS

(P) BOUNDARY LINE

Know what's below.

Call before you dig.

WATER SERVICE

PRELIMINARY
NOT FOR
CONSTRUCTION

DISCLAIMER

THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER.

	• • • • • • • • • • • • • • • • • • • •	AUTHORIZED USE IS PROHIBITED. N 018–711–33 & –34 (PART)	APPLICATION NO. 2138
	e	JULY 15, 2022 - 4TH SUBMITTAL	
	REVISED	APRIL 29, 2022 - 3RD SUBMITTAL	
	RE	JANUARY 14, 2022 - 2ND SUBMITTAL	
		BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS AND LAND SURVEYORS	COVER SHEET
,		3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073–2094 (831) 426–3560	GBxMB WATSONVILLE 200 MANABE OW ROAD


WATSONVILLE, CALIFORNIA DRAWN SCALE AS SHOWN JOB NO. 28503 DATE SEPTEMBER 30, 2021 CHECKED INDEX PAJARO 2 DWG NAME FILE NO. 28503


Attachment 1 Page 14 of 44

FILE NO. 28503

DESIGN


FILE NO. 28503





FILE NO. 28503

Page 19 of 44



GREEN-COLORED PAVEMENT FOR BIKE LANES

THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF

APPLICATION NO. 2138

DWG NAME

OFFSITE STRIPING PLAN


GB×MB WATSONVILLE 200 MANABE OW ROAD WATSONVILLE, CALIFORNIA JOB NO. 28503


INDEX PAJARO 2


FILE NO. 28503


CONSTRUCTION

Attachment 1 Page 21 of 44












DISCLAIMER

THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER. UNAUTHORIZED USE IS PROHIBITED.

APN 018-711-33 & -34 (PART) APPLICATION NO. 2138

D JULY 15, 2022 - 4TH SUBMITTAL



BOWMAN & WILLIAMS

CONSULTING CIVIL ENGINEERS

AND LAND SURVEYORS

3949 RESEARCH PARK COURT, SUITE 100

SOQUEL, CA 95073-2094

APRIL 29, 2022 - 3RD SUBMITTAL

JANUARY 14, 2022 - 2ND SUBMITTAL

SOQUEL, CA 95073-2094
(831) 426-3560

GBxMB WATSONVILLE
200 MANABE OW ROAD
WATSONVILLE, CALIFORNIA

SCALE 1" = 40'

DRAWN


JOB NO. 28503

PRELIMINARY
NOT FOR
CONSTRUCTION


PRELIMINARY CROSS


SECTIONS

12' WIDE
WATER LINE
ESMT



<u>RETAINING WALL 2</u>







DISCLAIMER THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER. UNAUTHORIZED USE IS PROHIBITED.

APN 018-711-33 & -34 (PART)

APPLICATION NO. 2138 JULY 15, 2022 - 4TH SUBMITTAL



PRELIMINARY

NOT FOR

CONSTRUCTION

BOWMAN & WILLIAMS

CONSULTING CIVIL ENGINEERS

AND LAND SURVEYORS

APRIL 29, 2022 - 3RD SUBMITTAL JANUARY 14, 2022 - 2ND SUBMITTAL

> PRELIMINARY RETAINING WALL PROFILES

3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073—2094 (831) 426—3560

GB×MB WATSONVILLE 200 MANABE OW ROAD WATSONVILLE, CALIFORNIA

SCALE 1" = 20' DRAWN JOB NO. 28503 DATE SEPTEMBER 30, 2021 CHECKED INDEX PAJARO 2 DESIGN

EXCERPTED FROM THE PRELIMINARY GEOTECHNICAL ENGINEERING REPORT FOR THE PROPOSED INDUSTRIAL PARK DEVELOPMENT (WEST PARCEL) SWC OHOLNE PARKWAY AND MANABE OW ROAD WASTONVILLE, CA PREPARED FOR FOUR STONES REAL ESTATE, LLC BY PROFESSIONAL SERVICE INDUSTRIES, INC. (PSI) PSI PROJECT NO. 575—1751—1 MARCH <u>23, 2021</u>

SITE PREPARATION

PRIOR TO CONSTRUCTION, ANY EXISTING UNDERGROUND UTILITIES SHOULD BE PROPERLY CAPPED OFF AT THE PROPERTY BOUNDARY AND REMOVED OR BE RE ROUTED AROUND THE NEW DEVELOPMENT. THE SITE SHOULD ALSO BE CLEARED OF SURFACE VEGETATION. AS A MINIMUM, IT IS RECOMMENDED THE CLEARING OPERATIONS EXTEND AT LEAST FIVE FEET BEYOND THE DEVELOPMENT PERIMETERS, WHERE POSSIBLE. PSI RECOMMENDS THAT AT THE TIME OF INITIAL SITE STRIPPING AND GRADING, THAT PSI BE RETAINED TO OBSERVE THE SUBGRADE CONDITIONS TO VERIFY THAT NO POTENTIALLY DELETERIOUS SOILS ARE PRESENT WITHIN SITE SUBGRADES PRIOR TO FILLING ABOVE.

FOLLOWING SITE CLEARING AND LOWERING OF SITE GRADES, WHERE NECESSARY, WE RECOMMEND THAT THAT THE EXPOSED SUBGRADE SOILS BE PROOF ROLLED WITH A HEAVY RUBBER TIRED PIECE OF CONSTRUCTION EQUIPMENT (MINIMUM 15 TON) APPROVED BY AND IN THE PRESENCE OF THE GEOTECHNICAL ENGINEER. ANY SOIL THAT EXCESSIVELY YIELDS OR RUTS DURING THE PROOF ROLL OPERATION SHOULD BE REMOVED AS RECOMMENDED BY THE GEOTECHNICAL ENGINEER. FOLLOWING PROOF ROLLING, THE EXPOSED SUBGRADE SHOULD BE SCARIFIED TO A DEPTH OF ABOUT 12 INCHES, MOISTURE CONDITIONED TO 0 TO +4 PERCENT (FINE GRAINED SOILS) ABOVE THE SOIL'S OPTIMUM MOISTURE CONTENT AND THEN BE COMPACTED TO AT LEAST 90% OF THE SOIL'S MAXIMUM DRY DENSITY PER ASTM D1557.

GRADING OPERATIONS SHOULD BE PERFORMED IN ACCORDANCE WITH OUR RECOMMENDATIONS, THE REQUIREMENTS OF THE CURRENT EDITION OF THE CBC, AND LOCAL GOVERNMENTAL STANDARDS WHICH HAVE JURISDICTION OVER THIS PROJECT.

EXCAVATIONS

EXCAVATION AND CONSTRUCTION OPERATIONS MAY EXPOSE THE ON SITE NEAR SURFACE SOILS TO INCLEMENT WEATHER CONDITIONS. THE STABILITY OF EXPOSED SOILS WILL RAPIDLY DETERIORATE DUE TO DRYING OR WETTING OR THE ACTION OF HEAVY OR REPEATED CONSTRUCTION TRAFFIC. ACCORDINGLY, FOUNDATION AREA EXCAVATIONS AND PAVEMENT SUBGRADE AREAS SHOULD BE ADEQUATELY PROTECTED FROM THE ELEMENTS, AND FROM THE ACTION OF REPETITIVE OR HEAVY CONSTRUCTION LOADING.

EXCAVATIONS/SLOPES

PERMANENT CUT OR FILL SLOPES SHOULD NOT EXCEED 3 HORIZONTAL TO 1 VERTICAL (3H:1V). EXCAVATIONS EXTENDING BELOW A 1H:1V PLANE EXTENDING DOWN FROM ANY ADJACENT FOOTINGS SHOULD BE SHORED FOR SAFETY. ALL EXCAVATIONS SHOULD BE INSPECTED BY A REPRESENTATIVE OF THE GEOTECHNICAL ENGINEER DURING CONSTRUCTION TO ALLOW MODIFICATIONS TO BE MADE DUE TO VARIATION IN THE SOIL TYPES. ALL WORK SHOULD BE PERFORMED IN ACCORDANCE WITH DEPARTMENT OF LABOR OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA) GUIDELINES. JOB SITE SAFETY IS THE RESPONSIBILITY OF THE PROJECT CONTRACTOR.

IN FEDERAL REGISTER, VOLUME 54, NO. 209 (OCTOBER 1989), THE UNITED STATES DEPARTMENT OF LABOR, OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA) AMENDED ITS "CONSTRUCTION STANDARDS FOR EXCAVATIONS, 29 CFR, PART 1926, SUBPART P". THIS DOCUMENT WAS ISSUED TO PROTECT THE SAFETY OF PERSONNEL ENTERING TRENCHES OR EXCAVATIONS. IT IS MANDATED BY THIS FEDERAL REGULATION THAT EXCAVATIONS, WHETHER THEY BE UTILITY TRENCHES, BASEMENT EXCAVATIONS, OR FOOTING EXCAVATIONS, BE CONSTRUCTED IN ACCORDANCE WITH THE NEW OSHA

THE CONTRACTOR IS SOLELY RESPONSIBLE FOR DESIGNING AND CONSTRUCTING STABLE, TEMPORARY EXCAVATIONS AND SHOULD SHORE, SLOPE, OR BENCH THE SIDES OF THE EXCAVATIONS AS REQUIRED TO MAINTAIN STABILITY OF BOTH THE EXCAVATION SIDES AND BOTTOM. THE CONTRACTOR'S "RESPONSIBLE PERSON," AS DEFINED IN 29 CFR PART 1926, SHOULD EVALUATE THE SOIL EXPOSED IN THE EXCAVATIONS AS PART OF THE CONTRACTOR'S SAFETY PROCEDURES. IN NO CASE SHOULD SLOPE HEIGHT, SLOPE INCLINATION, OR EXCAVATION DEPTH, INCLUDING UTILITY TRENCH EXCAVATION DEPTH, EXCEED THOSE SPECIFIED IN LOCAL, STATE, AND FEDERAL STATE REGULATIONS.

WE ARE PROVIDING THIS INFORMATION SOLELY AS A SERVICE TO OUR CLIENT. PSI DOES NOT ASSUME RESPONSIBILITY FOR CONSTRUCTION SITE SAFETY OR THE CONTRACTOR'S OR OTHER PARTIES' COMPLIANCE WITH LOCAL, STATE, AND FEDERAL SAFETY OR OTHER REGULATIONS.

UTILITY TRENCH BACKFILL

EXCAVATIONS SHOULD BE PERFORMED IN ACCORDANCE WITH APPLICABLE FEDERAL AND STATE OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION REGULATIONS. UTILITY TRENCHES IN THE SOILS AT THE SITE BELOW A DEPTH OF ABOUT 4

FEET WILL NEED TO BE SLOPED OR SHORED FROM THE GROUND SURFACE DUE TO THE POTENTIAL FOR CAVING. ACTUAL INCLINATIONS WILL ULTIMATELY DEPEND ON THE SOIL CONDITIONS ENCOUNTERED DURING EARTHWORK. WHILE WE MAY PROVIDE CERTAIN APPROACHES FOR TRENCH EXCAVATIONS, THE CONTRACTOR SHOULD BE RESPONSIBLE FOR SELECTING THE EXCAVATION TECHNIQUE, MONITORING THE TRENCH EXCAVATIONS FOR SAFETY, AND PROVIDING SHORING, AS REQUIRED, TO PROTECT PERSONNEL AND ADJACENT IMPROVEMENTS. THE INFORMATION PROVIDED BELOW IS FOR USE BY THE OWNER AND ENGINEER AND SHOULD NOT BE INTERPRETED TO MEAN THAT PSI IS ASSUMING RESPONSIBILITY FOR THE CONTRACTOR'S ACTIONS OR SITE SAFETY. THE SOILS ENCOUNTERED IN OUR SUBSURFACE EXPLORATIONS SHOULD BE CLASSIFIED AS TYPE B SOIL FOR TEMPORARY SLOPES, PROVIDED GROUNDWATER IS NOT OBSERVED; HOWEVER, A COMPETENT PERSON AS DEFINED BY OSHA SHOULD MAKE THE APPROPRIATE EVALUATION AND CLASSIFICATION DURING CONSTRUCTION. ACCORDING TO THE MOST RECENT OSHA REGULATIONS TEMPORARY EXCAVATIONS MAY BE SLOPED, WITHOUT SHORING AT NO STEEPER THAN 1H:1V (FOR TYPE B CONDITIONS) TO A MAXIMUM HEIGHT OF

THOUGH NOT ANTICIPATED, IF GROUNDWATER IS OBSERVED IN EXCAVATION AREAS PSI SHOULD BE NOTIFIED AND ALLOWED TO REASSESS OUR TEMPORARY SLOPING RECOMMENDATIONS. IN OUR OPINION, EXCAVATIONS SHOULD BE SAFELY SLOPED OR SHORED. THE CONTRACTOR SHOULD BE AWARE THAT EXCAVATION AND SHORING SHOULD CONFORM TO THE REQUIREMENTS SPECIFIED IN THE APPLICABLE LOCAL, STATE, AND FEDERAL SAFETY REGULATIONS, SUCH AS OSHA HEALTH AND SAFETY STANDARDS FOR EXCAVATIONS, 29 CFR PART 1926, OR SUCCESSOR REGULATIONS. WE UNDERSTAND THAT SUCH REGULATIONS ARE BEING STRICTLY ENFORCED, AND IF NOT FOLLOWED, THE CONTRACTOR MAY BE LIABLE FOR SUBSTANTIAL PENALTIES.

UTILITY TRENCHES BELOW THE SLAB, FOOTINGS AND PAVEMENT AREAS SHOULD BE BACKFILLED WITH PROPERLY COMPACTED ENGINEERED FILL ABOVE BEDDING AND SHADING FILL. BEDDING AND SHADING FILL AROUND UTILITIES IS TYPICALLY PERFORMED WITH GRANULAR SOIL ACCORDING TO LOCAL REQUIREMENTS. WHERE UTILITIES CROSS BUILDING PERIMETERS, SLURRY OR CONCRETE SHOULD BE USED FOR BACKFILL AROUND THE UTILITY TO PREVENT MOISTURE FROM MIGRATING ALONG THE UTILITY TRENCH AND ENTERING THE BUILDING ENVELOPE.

CONCRETE SLABS-ON-GRADE

CONCRETE SLAB-ON-GRADE WILL LIKELY SETTLE DUE TO CONSOLIDATION OF DEEP-SEATED SOIL STRATA UNDER THE PROPOSED FILL AND SURCHARGE FILL LOAD IF CONSTRUCTED PRIOR TO COMPLETING THE SETTLEMENT MONITORING PROGRAM. POTENTIAL CRACKING AND MOVEMENTS OF SLAB SHOULD BE EXPECTED IF THE SETTLEMENT MONITORING PROGRAM IS NOT COMPLETED. CONCRETE SLAB-ON-GRADE FLOOR SLABS FOR THE BUILDING SHOULD BE SUPPORTED ON SUITABLE FIRM AND UNYIELDING ENGINEERED FILL IN ACCORDANCE WITH THE RECOMMENDATIONS OF THIS

FOR THE SUBGRADE PREPARED AS RECOMMENDED OR FOR PROPERLY COMPACTED FILL, A MODULUS OF SUBGRADE REACTION (K) OF 225 POUNDS PER CUBIC INCH (PCI) MAY BE USED IN THE GRADE SLAB DESIGN BASED ON VALUES TYPICALLY OBTAINED FROM 1-FOOT BY 1-FOOT PLATE LOAD TESTS. HOWEVER, DEPENDING ON HOW THE SLAB LOAD IS APPLIED, THE VALUE WILL HAVE TO BE GEOMETRICALLY MODIFIED.

SLAB THICKNESS AND REINFORCEMENT DESIGN SHOULD BE PROVIDED BY THE STRUCTURAL ENGINEER. CARE SHOULD BE TAKEN BY THE CONTRACTOR TO ENSURE THAT THE REINFORCEMENT IS PLACED AND MAINTAINED AT SLAB MID-HEIGHT. FLOOR SLABS SHOULD BE SUITABLY REINFORCED AND JOINTED SO THAT A SMALL AMOUNT OF INDEPENDENT MOVEMENT CAN OCCUR WITHOUT CAUSING DAMAGE.

INTERIOR FLOOR SLABS SHOULD BE UNDERLAIN BY CAPILLARY BREAK MATERIAL THAT IS AT LEAST 4 INCHES THICK, CONSISTING OF CLEAN SAND. GRAVEL MAY BE USED FOR CAPILLARY BREAK MATERIAL SUCH THAT IT DOES NOT PUNCTURE THE VAPOR BARRIER (ROUNDED GRAVEL). IF THE STRUCTURAL ENGINEER DESIRES TO PLACE THE VAPOR BARRIER DIRECTLY BENEATH CONCRETE SLABS, THE CONCRETE MIX MUST BE DESIGNED TO ADDRESS BLEEDING, SHRINKAGE, AND CURLING PER AMERICAN CONCRETE INSTITUTE (ACI) 302.1R-15. IN MOISTURE-SENSITIVE FLOORING AREAS OR AREAS USED TO STORE MOISTURE-SENSITIVE MATERIALS, SUCH AS CARPETED OR LINOLEUM COVERED AREAS, A MOISTURE RETARDER SHOULD BE PLACED BENEATH THE SLAB. THE MOISTURE RETARDER SHEET SHOULD BE SEALED ALONG THE EDGES TO PREVENT LATERAL MIGRATION OF SOIL MOISTURE FROM ADJACENT NON-VISQUEEN AREAS. PRIOR TO PLACEMENT OF CLEAN SAND AND SLAB-ON-GRADE, THE MOISTURE RETARDER SHOULD BE THOROUGHLY INSPECTED FOR CRACKS, PUNCTURES, TEARS, AND HOLES. IF NECESSARY, THE MOISTURE RETARDER SHOULD BE REPLACED OR PATCHED TO ASSURE A FULLY FUNCTIONAL ENTITY.

SOME MINOR CRACKING OF SLABS CAN BE EXPECTED DUE TO SHRINKAGE. THE POTENTIAL FOR THIS SLAB CRACKING CAN BE REDUCED BY CAREFUL CONTROL OF WATER/CEMENT RATIOS IN THE CONCRETE. THE CONTRACTOR SHOULD TAKE APPROPRIATE CURING PRECAUTIONS DURING THE POURING OF CONCRETE IN HOT WEATHER TO REDUCE CRACKING OF SLABS. WE RECOMMEND THAT A SLIPSHEET (OR EQUIVALENT) BE UTILIZED IF GROUTED FILL, TILE, OR OTHER MOISTURE-SENSITIVE FLOOR COVÈRING IS PLANNÉD DIRECTLY ON CONCRETE SLABS. ALL SLABS SHOULD BE DESIGNED IN ACCORDANCE WITH STRUCTURAL CONSIDERATIONS. THE FLOOR SLAB SHOULD BE LIBERALLY JOINTED IN ACCORDANCE WITH ACI GUIDELINES TO HELP CONTROL CRACKING, RESULTING FROM DIFFERENTIAL MOVEMENT AND CONCRETE SHRINKAGE.

CONSTRUCTION CONSIDERATIONS

WE RECOMMEND THAT PSI BE RETAINED TO PROVIDE OBSERVATION AND TESTING DURING CONSTRUCTION, AND DURING EARTHWORK, PAVEMENT, AND OTHER GEOTECHNICAL RELATED CONSTRUCTION ACTIVITIES OF THIS PROJECT. PSI CANNOT ACCEPT ANY RESPONSIBILITY FOR ANY CONDITIONS WHICH DEVIATE FROM THOSE DESCRIBED IN THIS REPORT IF NOT ENGAGED TO ALSO PROVIDE CONSTRUCTION OBSERVATION AND TESTING FOR THIS PROJECT.

DRAINAGE AND LANDSCAPE CONSIDERATIONS

SURFACE WATER MUST NOT BE ALLOWED TO POND ADJACENT TO THE PROPOSED FUTURE FOUNDATIONS. TO PRECLUDE DRAINAGE PROBLEMS. WE RECOMMEND CONTINUOUS ROOF GUTTERS FOR THE PROPOSED STRUCTURE. WE RECOMMEND THAT ROOF DRAINS BE CONNECTED TO A TIGHT-LINE PIPE LEADING TO STORM DRAIN FACILITIES OR OTHER SUITABLE DISCHARGE LOCATIONS. PAVEMENT SURFACES AND OPEN SPACE AREAS SHOULD BE SLOPED SUCH THAT SURFACE WATER RUNOFF IS COLLECTED AND ROUTED TO SUITABLE DISCHARGE POINTS. WE ALSO RECOMMEND THAT GROUND SURFACES ADJACENT TO BUILDINGS BE SLOPED TO FACILITATE POSITIVE DRAINAGE AWAY FROM THE BUILDINGS.

A POSITIVE SLOPE GRADIENT OF 5 PERCENT DOWN AND AWAY FROM THE BUILDING PERIMETERS SHOULD BE APPLIED TO THE FINISHED SUBGRADE (INCLUSIVE OF TOPSOIL). THIS SLOPE SHOULD EXTEND NO LESS THAN 10 FEET AWAY FROM THE OUTSIDE BUILDING PERIMETER, WITH DRAINAGE SWALES PROVIDED TO REMOVE RUNOFF FROM AROUND THE STRUCTURE. ANY UTILITY TRENCH THAT ENTERS THE PERIMETER OF A STRUCTURE SHOULD BE EXCAVATED WITH A SLIGHT SLOPE DOWN AND AWAY FROM THE PERIMETER OF THE STRUCTURE.

LANDSCAPING AND IRRIGATION SHOULD NOT BE PLACED WITHIN 5 FEET OF PROPOSED STRUCTURE. TREES AND SHRUBS SHOULD BE POSITIONED A DISTANCE AWAY FROM THE STRUCTURE EQUAL TO HALF OF THEIR MATURE HEIGHT. WHERE CONCRETE FLATWORK SUCH AS SIDEWALKS ARE PLACED NEXT TO THE STRUCTURE, CONCRETE SHOULD BE PLACED ADJACENT TO THE FOUNDATION TO PREVENT A PLANTER STRIP THAT WOULD TRAP SURFACE WATER BETWEEN THE FOUNDATION AND THE SIDEWALK. IF VEGETATION IS PLANTED NEAR THE BUILDINGS, PLANTS THAT REQUIRE VERY LITTLE MOISTURE SHOULD BE USED. IRRIGATION SYSTEMS (DRIP AND/OR SPRINKLER HEADS) SHOULD NOT DIRECT WATER WHERE IT COULD SATURATE FOUNDATION SOIL. IF LANDSCAPING IS DESIRED CLOSER TO BUILDINGS, MOISTURE BARRIERS MAY BE CONSTRUCTED ADJACENT TO THE FOUNDATIONS TO MINIMIZE INFILTRATION BELOW. DETAILS CAN BE PROVIDED IF DESIRED.

PAVEMENT RECOMMENDATIONS

SUBGRADE SOILS FOR NEW PAVEMENTS SHOULD BE PREPARED IN GENERAL ACCORDANCE WITH THE SITE PREPARATION RECOMMENDATIONS (SECTION 4.2), TOGETHER WITH LIME-TREATMENT (SECTION 4.3) AND ENGINEERED FILL AND SURCHARGE FILL (SECTION 4.4) RECOMMENDATIONS.

PAVING WILL LIKELY CRACK DUE TO CONSOLIDATION OF DEEP-SEATED SOIL STRATA UNDER THE PROPOSED FILL AND SURCHARGE FILL LOAD IF THE SETTLEMENT MONITORING PROGRAM IS NOT COMPLETED. MAINTENANCE AND REPLACEMENT OF SITE PAVING SHOULD BE EXPECTED.

WHILE SPECIFIC TRAFFIC LOADS AND VOLUMES FOR THE PROJECT HAVE NOT BEEN PROVIDED, WE ARE PROVIDING RECOMMENDED LIGHT-DUTY AND MEDIUM TO HEAVY-DUTY PAVEMENT SECTIONS, WHICH HAVE BEEN SUCCESSFULLY UTILIZED FOR THIS TYPE OF DEVELOPMENT IN THE PROJECT AREA WITH SIMILAR TRAFFIC LOADING. FOR THESE PAVEMENT SECTIONS, WE HAVE ASSUMED AN R-VALUE OF 25 FOR THE SITE SUBGRADE SOILS AND A TRAFFIC INDEX OF 5.0 AND 7.0 FOR THE LIGHT DUTY AND MEDIUM TO HEAVY-DUTY SECTIONS, RESPECTIVELY.

ASPHALTIC CONCRETE (AC):

LIGHT DUTY (AUTOMOBILE PARKING; TI=5.0)

3 INCHES ASPHALT CONCRETE (CALTRANS STANDARD SPECS. SECTION 39) 8 INCHES CLASS II AGGREGATE BASE (CALTRANS STANDARD SPECS. SECTION 26) 12 INCHES COMPACTED SOIL SUBGRADE

MEDIUM TO HEAVY-DUTY (ENTRANCE AND DRIVE LANES; TI=7.0)

3½ INCHES ASPHALT CONCRETE (CALTRANS STANDARD SPECS. SECTION 39) 14 INCHES CLASS II AGGREGATE BASE (CALTRANS STANDARD SPECS. SECTION 26) 12 INCHES COMPACTED SOIL SUBGRADE

R-VALUE TESTING SHOULD BE PERFORMED ON THE ACTUAL PAVEMENT SUBGRADE MATERIAL AT THE TIME OF SITE GRADING.

AS AN ALTERNATE, CONCRETE PAVEMENT COULD ALSO BE USED AT THE SITE. BASED ON THIS, WE OFFER THE FOLLOWING CONCRETE PAVEMENT RECOMMENDATIONS:

PORTLAND CEMENT CONCRETE (PCC):

6 INCHES PORTLAND CEMENT CONCRETE

4 INCHES CLASS II AGGREGATE BASE (CALTRANS STANDARD SPECS. SECTION 26) 12 INCHES COMPACTED SOIL SUBGRADE

MEDIUM TO HEAVY DUTY SECTION (T.I.=7.0)

6½ INCHES PORTLAND CEMENT CONCRETE

6 INCHES CLASS II AGGREGATE BASE (CALTRANS STANDARD SPECS. SECTION 26) 12 INCHES COMPACTED SOIL SUBGRADE

THE MEDIUM TO HEAVY-DUTY RIGID PAVEMENT SECTION PRESENTED ABOVE MERITS CONSIDERATION FOR AREAS TO RECEIVE RELATIVELY HIGH CONCENTRATED SUSTAINED LOADS AND BRAKING, SUCH AS AT TRASH DUMPSTER ENCLOSURES, DRIVEWAY ENTRANCES, AND LOADING/STORAGE AREAS.

BASED ON THE NEAR SURFACE SOIL ENCOUNTERED IN THE BORINGS, IT IS OUR OPINION THAT A MODULUS OF SUBGRADE REACTION (K) OF 125 POUNDS PER SQUARE INCH PER INCH (PSI/IN) IS SUITABLE FOR CONCRETE PAVEMENT SECTIONS, GIVEN THE PRESENCE OF THE UNDERLYING BASE COURSE.

BASED ON OUR LOCAL EXPERIENCE, RIGID CONCRETE PAVEMENTS ARE CONSIDERED A PART OF THE CIVIL SITE WORK PACKAGE AND THE CONCRETE MIX DESIGN SPECIFICATIONS AND REBAR REINFORCEMENT DETAILING IS DEVELOPED AS PART OF THE PROJECT SPECIFICATIONS, TYPICALLY BY THE CIVIL ENGINEER. MINIMUM CEMENT CONTENTS AND CEMENTITIOUS MATERIAL REPLACEMENT SPECIFICATIONS SHOULD CONSIDER THE TIME OF YEAR FOR CONCRETE PLACEMENT FOR OPTIMAL MATERIAL PERFORMANCE. THE DESIGN PROJECT ENGINEER OF RECORD IS BEST QUALIFIED TO BE FAMILIAR WITH THE PROJECT SCHEDULE AND TO ESTABLISH THOSE PARAMETERS. MAKING SOME TYPICAL ASSUMPTIONS, HOWEVER, PSI PROVIDES THE FOLLOWING RECOMMENDATIONS.

PSI RECOMMENDS THAT THE CONCRETE SHOULD HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 4,000 PSI. THE CONCRETE PAVEMENTS SHOULD BE PROPERLY REINFORCED AND JOINTED (PER ACI REQUIREMENTS).

SAW CUT CONTROL JOINTS SHOULD BE PLACED AT MAXIMUM 15-FOOT INTERVALS AND SHOULD BE CUT AT A DEPTH OF AT LEAST ONE-QUARTER OF THE PAVEMENT THICKNESS. SAW CUT CONTROL JOINTS SPACED AT 10 FEET USUALLY CONTROL CRACKING BETTER THAN THE 15-FOOT INTERVAL. JOINTS SHOULD BE SAWED WITHIN 12 HOURS OF CONCRETE PLACEMENT, AND PREFERABLY SOONER. ALL JOINT SPACING IN LARGE PAVEMENT AREAS SHOULD BE SPACED IN ACCORDANCE WITH THE ACI STANDARD OR OTHER LOCAL REQUIREMENTS, IF STRICTER THAN THOSE SET BY ACI.


EXPANSION JOINTS SHOULD BE USED WHEREVER THE PAVEMENT WILL ABUT A STRUCTURAL ELEMENT SUBJECT TO A DIFFERENT MAGNITUDE OF MOVEMENT, SUCH AS: LIGHT POLES, CANOPIES, RETAINING WALLS, OR MANHOLES. EXPANSION JOINTS SHOULD BE SEALED WITH A POLYURETHANE SEALANT SO THAT MOISTURE INFILTRATION INTO THE SUBGRADE SOILS AND RESULTANT CONCRETE DETERIORATION AT THE JOINTS IS MINIMIZED.

GENERAL PAVEMENT NOTES

ALL AGGREGATE BASE AND THE UPPER 12 INCHES OF SUBGRADE SHOULD BE COMPACTED TO AT LEAST 95 PERCENT OF THE MAXIMUM DRY DENSITY AS DETERMINED BY ASTM D1557. MODIFIED PROCTOR. MOISTURE CONTENTS SHOULD BE KEPT WITHIN +2 PERCENT FOR BASE MATERIALS AND O TO 4 PERCENT FOR FINE GRAINED MATERIALS. ALL MATERIALS AND METHODS OF CONSTRUCTION SHOULD CONFORM TO GOOD ENGINEERING PRACTICES AND BE IN CONFORMANCE WITH THE REQUIREMENTS OF THE LOCAL JURISDICTION.

THE ABOVE RECOMMENDED PAVEMENT SECTIONS REPRESENT MINIMUM DESIGN THICKNESSES AND, AS SUCH, PERIODIC MAINTENANCE SHOULD BE ANTICIPATED. ALSO, THESE RECOMMENDED PAVEMENT SECTIONS SHOULD BE CONFIRMED OR MODIFIED BY YOUR CIVIL ENGINEER, BASED ON ACTUAL TRAFFIC AND THE OWNER'S REQUIREMENTS. THE PAVEMENT SECTION MATERIALS AND CONSTRUCTION SHOULD COMPLY WITH THE CALTRANS STANDARD SPECIFICATIONS AND LOCAL MUNICIPALITY REQUIREMENTS.

WHERE PAVEMENT AREAS ARE ADJACENT TO HEAVILY WATERED LANDSCAPING AREAS. WE RECOMMEND SOME MEASURE OF MOISTURE CONTROL BE TAKEN TO PREVENT THE SUBGRADE SOILS FROM BECOMING SATURATED. IT IS RECOMMENDED THAT THE CONCRETE CURBING ADJACENT TO THE LANDSCAPE AREAS EXTEND INTO THE PREPARED SUBGRADE TO REDUCE THE POTENTIAL FOR IRRIGATION WATER TO SATURATE SUBGRADE SOILS.





PROFESSI

1/ERANCIO

No. 53588

DISCLAIMER

THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED. OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER. UNAUTHORIZED USE IS PROHIBITED.

JULY 15, 2022 - 4TH SUBMITTAL APRIL 29, 2022 - 3RD SUBMITTAL JANUARY 14, 2022 - 2ND SUBMITTAL

BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS AND LAND SURVEYORS

APN 018-711-33 & -34 (PART)

GEOTECHNICAL RECOMMENDATIONS

3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073-2094 GBxMB WATSONVILLE (831) 426-3560 200 MANABE OW ROAD WATSONVILLE, CALIFORNIA

SCALE 1" = 20' DRAWN JOB NO. 28503 DATE SEPTEMBER 30, 20 CHECKED INDEX PAJARO 2 DESIGN DWG NAME FILE NO. 28503


PRELIMINARY NOT FOR CONSTRUCTION

APPLICATION NO. 2138


FILE NO. 28503

DWG NAME

DESIGN



FILE NO. 28503




STABILIZED

FILE NO. 28503

CONSTRUCTION

DESIGN



BOTTOM (SEE PLAN) --INSTALL 18" NYPOPLAST DRAIN **SECTION** BASIN WITH PERFORATIONS AT THE

- 1. TRAP LAYOUT MAY BE MODIFIED AS REQUIRED FOR SITE CONSTRUCTION AND ACCESS AS DIRECTED BY THE
- 2. REQUIRED SEDIMENT TRAP VOLUME = 67 CY/ACRE SETTLING + 33 CY/ACRE STORAGE= 100 CY /ACRE TOTAL

STORAGE & SETTLING VOLUME REQUIRED = 3.69 ACRES X 100 CY/ACRE = 369 CY (9,963 CF) STORAGE & SETTLING VOLUME PROVIDED = 12,992 S.F. X 1.0 FT = 12,992 CF TOTAL SEDIMENT TRAP DEPTH "D" = 1' (FREEBOARD) + 1' = 2'

SEDIMENT TRAP NO. 4


SEDIMENT TRAP DETAIL

SCALE: NTS

1. TRIBUTARY AREA = 1.95 ACRES, TRAP NO. 4 AVERAGE SURFACE AREA FOR 2' DEPTH 1' FREEBOARD WITH 3:1 SIDE SLOPES = 6,323 S.F.

2. STORAGE & SETTLING VOLUME REQUIRED= 1.95 ACRES X 100 CY/ACRE = 195 CY (5,265 CF) STORAGE & SETTLING VOLUME PROVIDED = 6,323 S.F. X 1.0 FT = 6,323 CF TOTAL SEDIMENT TRAP DEPTH "D" = 1' (FREEBOARD) + 1' = 2'

GRAPHIC SCALE (IN FEET)



1.77 4.71 0.38 0.010 **11.38**

Flow Rate Calculations f	ior Sedimer	nt Trap No	o. 3 - 100) Year E	vent		Flow Rate Calculations	for Sedimer	t Trap No	. 4 - 100	Year E	vent	
Weighted C Calculations for Post D	Development Su	<u>ırfaces</u>					Weighted C Calculations for Post I	Development Su	rfaces_				
Area Description	Area (ft2)	Area (AC)	С	A*C			Area Description	Area (ft2)	Area (AC)	С	A*C		
Rough Graded Areas	160,732	3.69	0.60	2.213939			Rough Graded Areas	84,885	1.95	0.60	1.169215		
	Total:	3.69		2.21				Total:	1.95		1.17		
	Weighted C=	0.60						Weighted C=	0.60				
Notation					Return Period	la	Notation					Return Period	la
Q _{Post} = Post Development Flow Rate Fo	For Proiect Area				2	0.64	Q _{Post} = Post Development Flow Rate F	or Project Area				2	0.64
Georgia Total Bereine File II. I.	1110,000,000				10	1.00	CPost - 1 OSt Development 1 low rate 1	OI FTOJECT AICA				10	1.00
					15	1.09						15	1.09
Basis of Calculation					25	1.20	Basis of Calculation					25	1.20
$I = ((4.29112)*(1.1952^{P60}))/(t_c^{(0.609)})$	924)*(0.78522 ^{P60} ,)) * <mark>l</mark> a			50	1.35	$I = ((4.29112)*(1.1952^{P60}))/(t_c^{(0.609)})$	924)*(0.78522 ^{P60})) * la			50	1.35
$Q = C^*C_a^*I^*A$	The state of the s				100	1.50	$Q = C^*C_a^*I^*A$					100	1.50
Intensity for Storm							Intensity for Storm						
Return Period =		Years					Return Period =		Years				
P60 Isopleth =		(Based on L		_			P60 Isopleth =	1.33	(Based on L	ocation - S	See County	Map)	
l _a =	1.5	(Based on Re	eturn Perioc	d - See Abov	<i>i</i> e Right)		l _a =	1.5	(Based on Re	eturn Period	d - See Abov	/e Right)	
	Runoff Fk	ow Calculation	ns					Runoff Flo	w Calculation	is			
Description	Area (ac)	С	Ca	T _c (min)	l (in/hr)	Q (cfs)	Description	Area (ac)	С	Ca	T _c (min)	l (in/hr)	Q (cfs)
Post Development - 100 Year Return	3.69	0.600	1.25	10	2.951	8.17	Post Development - 100 Year Return	1.95	0.600	1.25	10	2.951	4.31
Pipe Size Calculations							Pipe Size Calculations						
	Pipe Siz	e Calculations						Pipe Size	• Calculations				
Pipe Size	l n	A	Р	R	S	Qt	Pine Size	n	Δ	P	R	S	Ot



DISCLAIMER

THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER. UNAUTHORIZED USE IS PROHIBITED.

APN 018-711-33 & -34 (PART) APPLICATION NO. 2138 JULY 15, 2022 - 4TH SUBMITTAL



NOT FOR

BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS AND LAND SURVEYORS

APRIL 29, 2022 - 3RD SUBMITTAL

JANUARY 14, 2022 - 2ND SUBMITTAL

PHASE 1 PRELIMINARY SEDIMENT TRAPS SIZING & DETAILS 3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073-2094 GBxMB WATSONVILLE

1.77 4.71 0.38 0.020 **16.09**

0.012 1.77 4.71 0.38 0.020 **16.09**

(831) 426-3560 200 MANABE OW ROAD WATSONVILLE, CALIFORNIA **PRELIMINARY** SCALE 1" = 60'DRAWN JOB NO. 28503 CHECKED DATE SEPTEMBER 30, 202 INDEX PAJARO 2 CONSTRUCTION

1 inch = 60 ft.

DWG NAME FILE NO. 28503

Page 32 of 44

Temporary erosion control measures are effective during the rainy season (October 15 to April 15).

General Requirements


- 1. If any grading operations, other than lot finish grading, are to be performed during the rainy season, October 15 through April 15, an Erosion Control Plan must be submitted by August 15 and the plan must be approved by the City of Watsonville prior to the commencement of any such grading operations.
- 2. All erosion and sediment control measures shall be constructed and maintained in accordance with the *Erosion and Sediment Control Field Manual*, published by the California Regional Water Quality Control Board, Region 2, unless otherwise stated within these Standards. Recommended practices cited in these standards come from the Third Edition, July 1999. Control measures are subject to the inspection and approval of the City. Schedule an initial site inspection by calling 831-728-6018 at least 48 hours prior to the start of any work.
- 3. Except as otherwise directed by the Inspector, all devices shown on the Erosion Control Plan shall be in place at the end of each day. All erosion control facilities must be inspected and repaired by the owner/contractor at the end of each working day during the rainy season and maintained during the rainy season (October 15 to April 15). Any erosion control facilities that are disturbed during the work day must be in place and functional by the end of each day.
- 4. Temporary erosion control devices and Best Management Practices (BMPs) shall be relocated or modified only with approval of the Inspector.
- 5. The Permittee or Contractor shall be responsible for any and all emergency work during rainstorms.
- 6. Borrow areas and temporary stockpiles shall be protected with appropriate erosion control measures to the satisfaction of the Inspector. (Recommended Practices: Temporary seeding and mulching, p. 31; Hydromulching - hydroseeding, p. 35; Erosion control blankets and geotextiles, p. 45; Fiber rolls, p. 47).
- 7. Sufficient erosion control materials shall be stored on site and placed at intervals shown on erosion control plans.

Inspections

8. After October 15, all erosion control measures will be inspected by the City daily and after each storm. After October 15, damage to BMPs must be repaired at the close of each day and whenever rain is forecast.

Hydroseeding and Mulching

9. All graded areas with slopes in excess of 5% shall be hydroseeded per the Erosion and Sediment Control Field Manual, p. 35. In addition to hydroseeding, application of straw with a tackifier or mulch may be required by the City. Graded areas with slopes less than 5% shall be protected from erosion with straw and a tackifier. An approved mix design follows:




- THE CONTRACTOR SHALL EMPLOY A MONITORING STATION TO OBSERVE AND ASSESS THE
- 2. AT THE DIRECTION OF THE QSP, THE CONTRACTOR MAY DEPLOY A STREET SWEEPER TO CONTROL TRACKING.



C6.2

CONSTRUCTION ENTRANCE/EXIT



SAFETY FENCE DETAIL

SCALE: NTS

'Blando' Brome BROMUS CARINATI	JS 30 lbs./aere- 25 LBS./ACRE
Zorro Fescue ELYMUS GLAUC	JS 10 lbs./aere- 10 LBS./ACRE
Hykon Rose Clover VULPIA MICROSTACH	YS 12 lbs./acre 6 LBS./ACRE
California Native Wildflower TRIFOLIUM CILIAT	UM 8 lbs./acre 4 LBS./ACRE
Fertilizer (ammonium phosphate with sulfur, 16-20-0)	200 lbs./acre
Organic Binder	100 lbs./acre
Straw Mulch	4000 lbs./acre (about 45 bales/acre)

Note: Santa Cruz County Erosion Control Mix (used at 60 lbs/acre) may be used for the seedportion of the above mix.

Stormwater Conveyance

10. If the permanent storm drain system is not installed by October 1, temporary ditches shall **be constructed** to contain the storm water and direct it to sediment control facilities. Temporary ditches shall be lined with a suitable material that prevents erosion of the ditch.

Provide velocity check dams in all unpaved graded channels at the intervals indicated below. (Recommended Practices: Check dams, p. 57; Temporary straw bale dike, p. 65; Sand/gravel bag barrier, p. 69).

Grade of Channel	Interval
Less than 3%	100 feet
3% to 6%	50 feet
Over 6%	25 feet


11. All cut and fill slopes are to be protected to prevent overbank flow using 4" earth berms or sand bags. When directed by the Inspector, a 12-inch berm shall be maintained along the top of the slope of those fills on which grading is not in progress. (Recommended Practice: Sand/gravel bag barrier, p. 69).


12. Provide velocity check dams in all unpaved streets at the intervals indicated below. Velocity check dams may be constructed of straw bales, sandbags or other erosion resistant materials approved by the Inspector, and shall extend completely across the street or channel at right angles to the centerline. Earth dikes may not be used as velocity check dams. (Recommended Practices: Check dams, p. 57; Temporary straw bale dike, p. 65; Sand/gravel bag barrier, p. 69).


Grade of the Street	Interval
Less than 2%	As required
2% to 4%	100 feet
4% to 10%	50 feet
Over 10%	25 feet

____ 2" X 2" X 36" WOODEN STAKES PLACED 10' O.C. — FILTREXX® SOXX™ (12" TYPICAL) BLOWN/PLACED FILTER MEDIA™ AREA TO BE PROTECTED WORK AREA


SECTION NTS







TYPICAL SITE DRAIN INLET SECTION



STREET DRAIN INLET SECTION



DRAIN INLET PROTECTION SCALE:

Construction Entrances

13. The Contractor shall place drain rock as a gravel roadway (6" minimum thickness for the full width and 50 feet long) at each road entrance to the site. Any mud that is tracked onto public streets shall be removed the same day. (Recommended Practices: Stabilized construction entrance, p. 51; Entrance/exit tire wash, p. 53).

14. All soil and debris shall be removed from any street areas impacted by construction on a daily basis, or more frequently as directed by the Inspector. The site shall be maintained so as to minimize sediment laden runoff to any storm drain or natural drainage system.

Miscellaneous

15. Utility or storm drain trenches that are cut through basin dikes or basin inlet dikes, shall be plugged with sandbags from top of pipe to top of dike. Utility lines shall first be encased in concrete before sandbags are placed.

16. All open utility trenches shall be blocked at the prescribed intervals from the bottom to top with a double row of sandbags prior to backfill. Utility trenches shall be blocked at the prescribed intervals with a double row of sandbags extending two sandbags from the graded surface of the street. Sandbags are to be placed with alternate header and stretcher courses. The intervals prescribed between sandbag locking shall depend on the slope of the ground surface, but not exceed the following:

Grade of the Trench	Interval
Less than 2%	As required
2% to 4%	100 feet
4% to 10%	50 feet
Over 10%	25 feet


17. After utility trenches are backfilled and compacted, the surfaces over such trenches shall be mounded slightly to prevent channeling of water in the trench area. Care should be exercised to provide for cross flow at frequent intervals where trenches are not on the center line of a crowned street.


18. Hazardous materials and wastes, including petroleum products, asphalt products, pesticides, paints, stains, solvents, and concrete curing compounds must be properly stored and handled, as per the Erosion and Sediment Control Field Manual, p. 97-106.

19. Concrete mixing equipment and trucks must be cleaned in a properly constructed Concrete Washout Area as per the Erosion and Sediment Control Field Manual, p. 107. Concrete washout is not allowed to flow into streets, storm drains, or off of the construction site.

Erosion and Sediment Control Field Manual Third Edition, 1999


To order a copy of this Manual, contact Friends of the San Francisco Estuary, P.O. Box 791, Oakland, CA 94604-0791, call (510) 622-2419, or go to http://store.abag.ca.gov/construction.asp






NOTES:

- 1. SILT FENCE SHALL BE PLACED ON SLOPE CONTOURS TO MAXIMIZE PONDING EFFICIENCY.
- INSPECT AND REPAIR FENCE AFTER EACH STORM EVENT AND REMOVE SEDIMENT WHEN NECESSARY. 9" MAXIMUM RECOMMENDED STORAGE HEIGHT.
- REMOVED SEDIMENT SHALL BE DEPOSITED TO AN AREA THAT WILL NOT CONTRIBUTE SEDIMENT OFF-SITE AND CAN BE PERMANENTLY STABILIZED.







TYPICAL SLOPE EROSION CONTROL C6.2 SCALE: NTS



DISCLAIMER THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER. UNAUTHORIZED USE IS PROHIBITED. APPLICATION NO. 2138 APN 018-711-33 & -34 (PART)

3/4 IN. X 3/4 IN. WOOD STAKE



PRELIMINARY

NOT FOR

CONSTRUCTION

JANUARY 14, 2022 - 2ND SUBMITTAL BOWMAN & WILLIAMS

JULY 15, 2022 - 4TH SUBMITTAL

APRIL 29, 2022 - 3RD SUBMITTAL

CONSULTING CIVIL ENGINEERS AND LAND SURVEYORS 3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073-2094

GBxMB WATSONVILLE (831) 426-3560 200 MANABE OW ROAD WATSONVILLE, CALIFORNIA


SCALE AS SHOWN DRAWN JOB NO. 28503 CHECKED DATE SEPTEMBER 30, INDEX PAJARO 2


DWG NAME FILE NO. 28503


PRELIMINARY EROSION


CONTROL DETAILS













WATER MAINS SHALL BE DUCTILE IRON PIPE, CLASS 52, CONFORMING TO ANSI/AWWA SPECIFICATION C15/A.21.51. PIPES SHALL BE COATED WITH BITUMINOUS SEAL AND CEMENT MORTAR LINING CONFORMING TO ANSI/ AWWA SPECIFICATION C104/A21.4. THE COATING SHALL BE 1/16" THICK. JOINTS SHALL BE TYTON OR EQUAL RUBBER GASKET TYPE CONFORMING TO ANSI/AWWA SPECIFICATION C111/A21.11. CONTRACTOR SHALL ENCASE ALL NEW WATER MAINS WITH POLYWRAP MEETING AWWA C105-10.

SANITARY SEWER- GRAVITY MAIN

SANITARY SEWER GRAVITY MAINS SHALL BE P.V.C. PIPE, SDR-26 OR LESS.

SANITARY SEWER - FORCE MAIN

SANITARY SEWER FORCE MAINS SHALL BE C-900 CLASS 100 PVC WITH LOCATOR WIRE. THE WIRE SHALL BE A MINIMUM OF 12 GUAGE THW OR 12 GUAGE THWN, AND SHALL BE CONTINUOUS FOR THE ENTIRE LENGTH OF PIPE LAID BETWEEN CLEANOUTS. THE WIRE SHALL BE SECURED TO PIPE BY TAPE WRAPPED COMPLETELY AROUND PIPE EVERY 12 FEET OR LESS. THE WIRE SHALL BE BROUGHT INTO CLEANOUT MANHOLES WITH 2 FEET OF WIRE MORE THAN IS NEEDED TO REACH THE SURFACE.


STORM SEWER


STORM SEWER MAINS SHALL BE;


- CLASS III REINFORCED CONCRETE PIPE (RCP) WITH RUBBER ISOPRENE GASKETS


- PVC SDR-26 PIPE OR LESS.

- HIGH DENSITY POLYETEHYLENE (HDPE) CORRUGATED PIPE WITH SMOOTH INTERIOR WALLS (TYPE "S"), WITH RUBBER GASKETTED, WATER-TIGHT JOINTS MEETING THE REQUIRE-MENTS OF ASTM 3212 (ADS N12 OR APPROVED EQUAL).









TYPICAL AC PAVEMENT SECTION ****C7.1



DISCLAIMER THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER. UNAUTHORIZED USE IS PROHIBITED.

APN 018-711-33 & -34 (PART) JULY 15, 2022 - 4TH SUBMITTAL APRIL 29, 2022 - 3RD SUBMITTAL

JANUARY 14, 2022 - 2ND SUBMITTAL BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS

STANDARD DETAILS AND LAND SURVEYORS 3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073-2094 (831) 426-3560

GBxMB WATSONVILLE 200 MANABE OW ROAD WATSONVILLE, CALIFORNIA

APPLICATION NO. 2138

8.0"

8.0"


14.0"

CALTRANS CLASS 2

" NATIVE MATERIAL


ENGINEERED FILL OR (E)


SCALE AS SHOWN DRAWN JOB NO. 28503 DATE SEPTEMBER 30, 2021 CHECKED JFR INDEX PAJARO 2 **DWG NAME** FILE NO. 28503





NOT FOR CONSTRUCTION DESIGN

















POLY COATED TYPE K SOFT-

COPPER SERVICE TUBING


USE MUELLER 110 OR FORD-


COMPRESSION CORP STOP


TYPE "Q" BRASS


WATER MAIN


DWG NO. W-01















DISCLAIMER THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER.

UNAUTHORIZED USE IS PROHIBITED. APN 018-711-33 & -34 (PART) JULY 15, 2022 - 4TH SUBMITTAL

APRIL 29, 2022 - 3RD SUBMITTAL JANUARY 14, 2022 - 2ND SUBMITTAL BOWMAN & WILLIAMS

CONSULTING CIVIL ENGINEERS AND LAND SURVEYORS 3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073-2094 (831) 426-3560

WATSONVILLE, CALIFORNIA SCALE AS SHOWN DRAWN JOB NO. 28503 DATE SEPTEMBER 30, 2021 CHECKED JFR INDEX PAJARO 2 DESIGN DWG NAME 25918_C6 FILE NO. 28503



PRELIMINARY NOT FOR CONSTRUCTION


Page 36 of 44

APPLICATION NO. 2138

STANDARD DETAILS

GBxMB WATSONVILLE

200 MANABE OW ROAD



POLY COATED TYPE K SOFT-

COPPER SERVICE TUBING


ISE MUELLER 110 OR FORD TYPE "Q"—

FORD METER BRONZE DOUBLE—


CHECKED BY: TC


STRAP SADDLE STYLE 202B


WATER MAIN






















CLEANOUT (SDCO/SSCO) DETAIL

SCALE: 1"=1'-0"





SOQUEL, CA 95073-2094




WATSONVILLE, CALIFORNIA DRAWN JOB NO. 28503 CHECKED JFR INDEX PAJARO 2 DWG NAME FILE NO. 28503

APPLICATION NO. 2138


GBxMB WATSONVILLE

200 MANABE OW ROAD



SECTION B-B

C7.5



---- 3'-0" MIN -----

· 4"ø MIN PERF PIPE UNDERDRAIN

FACE DOWN WHERE OCCURS, 3"

w/ 3/8" HOLES OR SLOTS


ABOVE BOTTOM.

- SOIL MIX SHALL BE A WELL-BLENDED MIXTURE OF MINERAL AGGREGATE AND COMPOST MEASURED ON A VOLUME BASIS.
- 2. SOIL MIX SHALL CONSIST OF TWO PARTS COMPOST (35-40%) BY VOLUME AND TREE PARTS MINERAL AGGREGATE (60 TO 65%) BY VOLUME.
- 3. THE SOIL MIX SHALL BE WELL BLENDED TO PRODUCE A HOMOGENEOUS MIX.
- MINERAL AGGREGATE MIX SHALL BE ASTM C33 SAND OR APPROVED EQUAL.
- 5. SEE SHEET C6.1 FOR CURB, GUTTER & SIDEWALK DETAILS.

SECTION A-A

- 6. THESE CONDITIONS, 24" EFFECTIVE WIDTH AND 4" MIN PONDING, ARE ADEQUATE GIVEN THE CONSTRAINTS.
- AREA SHALL BE DRAINED WITH AN OVERFLOW STRUCTURE WITH BEEHIVE GRATE PER C.O.W. STD. DWG. NO. LID-003.





WEIR WIDTH, SEE TABLE

SEE TABLE FOR DIAMETER

SEE CONNECTION

SD OUT-

1/2" GALVANIZED STEEL PLATE

SECTION B-B


<u>PLAN</u>

ORIFICE INVERT ELEVATION


WEIR INVERT ELEVATION

ORIFICE DIAMETER (IN)

WEIR WIDTH (IN)




C7.5



TO DRAIN

GRAVEL SWALE DETAIL C7.5 SCALE: 3/4"=1'-0"



14.92

4 3/4

SCALE:

14.94

OUTLET CONTROL STRUCTURE (OCB) DETAILS

3/4"=1'-0"

<u>PLAN</u>

ENERGY DISSIPATER SCALE: 1/2" = 1'-0"

THE DATA SET FORTH ON THIS SHEET IS THE PROPERTY OF BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS. IT IS AN INSTRUMENT OF SERVICE AND MAY NOT BE REPRODUCED, ALTERED, OR USED WITHOUT THE CONSENT OF THE ENGINEER. THE PROPER ELECTRONIC TRANSFER OF DATA SHALL BE THE USER'S RESPONSIBILITY WITHOUT LIABILITY TO THE ENGINEER. UNAUTHORIZED USE IS PROHIBITED.

APN 018-711-33 & -34 (PART)

APPLICATION NO. 2138 JULY 15, 2022 - 4TH SUBMITTAL APRIL 29, 2022 - 3RD SUBMITTAL

_ SOLID LID TOP EL SEE PLAN

SECTION A-A

CONNECTION DETAIL

20.00 20.00

13.15

1 3/4

3 3/4

2 x 2 x 3/8 ANGLE -IRON, TYP. EACH

14.79 14.79

19.50

1 1/4

18.50

1 2/4 | 1 1/4 |

6" TEE ----

3 3/4 3

TOP OF WEIR WALL

ELEV. SEE TABLE

SEE TABLE FOR DIAMETER

WA372344SS

- 3/8" X 1 3/4" STAINLESS STEEL

S" SD FROM CB IN SWALE

EACH SIDE.

BOLTS WITH STAINLESS STEEL NUTS SPACED AT 7" O.C., OR EQUAL TYP.

EQUAL TYP. EACH SIDE,

3/8" X 2 3/4" SIMPSON WEDGE-ALL

STAINLESS STEEL ANCHOR, MODEL NO.

SPACED AT 7" O.C., STAGGERED, OR




BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS AND LAND SURVEYORS 3949 RESEARCH PARK COURT, SUITE 100 SOQUEL, CA 95073-2094

JANUARY 14, 2022 - 2ND SUBMITTAL

GBxMB WATSONVILLE 200 MANABE OW ROAD (831) 426-3560 WATSONVILLE, CALIFORNIA DRAWN JOB NO. 28503


STANDARD LID DETAILS

SCALE AS SHOWN DATE SEPTEMBER 30, 20 CHECKED JFR INDEX PAJARO 2 FILE NO. 28503 DWG NAME 24735_C7.1




DETENTION OVERFLOW STRUCTURE

SCALE: 1/2" = 1'-0"



C7.5



Symbol	Label	Image	Manufacturer	Catalog Number	Description	Lamp	Number Lamps	Filename	Lumens Per Lamp	Lumen Multiplie r	Light Loss Factor	Wattage	Efficiency	Distribut ion
	WM1		Lithonia Lighting	DSX1 LED P6 40K TFTM MVOLT HS	WALL LIGHT AT 20' WITH HOUSE SIDE SHIELD	LED	1	DSX1_LED_P6 _40K_TFTM_M VOLT_HS.ies	14863	1	0.85	163	100%	TYPE III VERY SHORT, BUG RATING: B2 - U0
	PL1		Lithonia Lighting	DSX1 LED P2 40K BLC MVOLT	2'-6" BASE, 17'-6" POLE, 20' MOUNTING WITH BACK LIGHT CONTROL	LED	1	DSX1_LED_P2 _40K_BLC_MV OLT.ies	7293	1	0.85	70	100%	TYPE III SHORT, BUG RATING B1 - U0 G2
	PL2		Lithonia Lighting	DSX1 LED P7 40K TFTM MVOLT HS	2'-6" BASE, 17'-6" POLE, 20' MOUNTING WITH HOUSE SIDE SHIELD	LED	1	DSX1_LED_P7 _40K_TFTM_M VOLT_HS.ies	16188	1	0.85	183	100%	TYPE III VERY SHORT, BUG RATING B2 - U0 G3
	PL3		Lithonia Lighting	DSX1 LED P6 40K T5M MVOLT	2'-6" BASE, 17'-6" POLE, 20' MOUNTING	LED	1	DSX1_LED_P6 _40K_T5M_MV OLT.ies	19765	1	0.85	163	100%	TYPE VS BUG RATING B4 - U0 G2
	PL5		Lithonia Lighting	DSX1 LED P7 40K T5W MVOLT	2'-6" BASE, 17'-6" POLE, 20' MOUNTING	LED	1	DSX1_LED_P7_ 40K_T5W_MVO LT.ies	21384	1	0.85	183	100%	TYPE VS BUG RATING B5 - U0 G3
	PL6		Lithonia Lighting	DSX1 LED P4 40K T5M MVOLT	2'-6" BASE, 17'-6" POLE, 20' MOUNTING	LED	1	DSX1_LED_P4_ 40K_T5M_MVOL T.ies	15042	1	0.85	125	100%	TYPE VS BUG RATING B4 - U0 G2

Statistics						
Description	Symbol	Avg	Max	Min	Max/Min	Avg/Mi
Calc Zone #3	+	2.0 fc	7.6 fc	0.1 fc	76.0:1	20.0:
PROPERTY LINE	+	0.0 fc	0.2 fc	0.0 fc	N/A	N/A

RYAN

RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

OWNE

CONSULTANTS







PROJECT INFORMATION

GBxMB Watsonville

WATSONVILLE, CA 95076

© 2021 RYAN A+E, INC.

701-048

DRAWN BY
Author
Checker

JOB NO.
DATE

2021-11-22


1 07-27-21 DESIGN REVIEW SUBMITTAL
2 09-30-21 DESIGN REVIEW RESUBMITTA
3 01-14-22 DESIGN REVIEW RESUBMITTA
4 04-18-22 DESIGN REVIEW RESUBMITTA
5 07-15-22 DESIGN REVIEW RESUBMITTA

DESIGN REVIEW
RESUBMITTAL


PHOTOMETRIC SITE PLAN


ES-100

1 PHOTOMETRIC SITE PLAN - TRUE NORTH ES-100 1" = 50'-0"



FIXTURE TYPES 'PL1', 'PL2', 'PL3', 'PL5', 'PL6'





RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

OWNER

CONSULTANTS



BW BOWMAN & WILLIAMS CONSULTING CIVIL ENGINEERS & LAND SURVEYORS



PROJECT INFORMATION

GBxMB Watsonville

WATSONVILLE, CA 95076


© 2021 RYAN A+E, INC.


CHECKED BY DRAWN BY Author Checker JOB NO. DATE 701-048 2021-11-22

1 07-27-21 DESIGN REVIEW SUBMITTAL 2 09-30-21 DESIGN REVIEW RESUBMITTA 3 01-14-22 DESIGN REVIEW RESUBMITTA 4 04-18-22 DESIGN REVIEW RESUBMITTA 5 07-15-22 DESIGN REVIEW RESUBMITTA

DESIGN REVIEW RESUBMITTAL 2021.12.28

FIXTURE CUT SHEETS





5 GAL

1 GAL

1 GAL

5 GAL

5 GAL

1 GAL

1,286

LOW

LOW

LOW

LOW

LOW

VERY LOW

BACCHARIS PILULARIS / COYOTE BUSH

MUHLENBERGIA RIGENS / DEER GRASS

JUNCUS PATENS / CALIFORNIA GRAY RUSH

SISYRINCHIUM BELLUM / BLUE EYED GRASS

MIMULUS GUTTATUS / YELLOW MONKEYFLOWER

RHAMNUS CALIFORNICA 'EVE CASE' / CALIFORNIA COFFEEBERRY

- 1. PLANT COUNTS SHOWN ARE FOR BIDDING REFERENCE ONLY. CONTRACTOR SHALL SUPPLY ALL PLANTS REQUIRED TO FULFILL DESIGN INTENT AS SHOWN. ADDITIONALLY, IF A GROUNDCOVER SYMBOL OR PATTERN IS SHOWN STOPPING AT THE EDGE OF A TREE OR SHRUB CANOPY SYMBOL, THE INTENT IS THAT THE GROUNDCOVER CONTINUE UNDERNEATH THE CANOPY SYMBOL(S) TO PROVIDE AN EVENLY COVERED
- 2. CONTRACTOR SHALL PROTECT AND MAINTAIN ALL PLANT MATERIAL FROM THE TIME OF DELIVERY TO THE TIME OF PROJECT ACCEPTANCE. THE OWNER SHALL NOT BE RESPONSIBLE FOR LOSSES DUE TO VANDALISM, THEFT, OR SEVERE WEATHER.
- 3. CONTRACTOR SHALL PLACE PLANT MATERIALS SO THEY DO NOT INTERFERE WITH IRRIGATION SYSTEM OR INHIBIT REQUIRED COVERAGE. PLANT LOCATIONS MAY BE ADJUSTED AS LONG AS DESIGN IS NOT ALTERED SIGNIFICANTLY. CONTRACTOR SHALL SET OUT PLANT MATERIAL IN THEIR CONTAINERS AS SHOWN AND RECEIVE ACCEPTANCE FROM PROJECT MANAGER WITH RESPECT TO PLANT HEALTH/APPEARANCE AND LOCATION PRIOR TO INSTALLATION. CONTRACTOR SHALL GIVE A MINIMUM OF 2 WORKING DAY NOTICE FOR INSPECTION/OBSERVATION AND SHALL HAVE ALL MATERIAL IN SPECIFIED LOCATIONS FOR REVIEW AT ONE
- 4. ALL NON-TURF PLANTING AREAS SHALL RECEIVE A PRE-EMERGENT HERBICIDE TREATMENT AND A 3" LAYER OF MAHOGANY COOLOR PRO CHIP MULCH TOP DRESS (1-3" PIECES-SUBMIT SAMPLES) AVAILABLE AT SOUTH BAY MATERIALS, SAN JOSE. REFER TO SPECIFICATIONS FOR ADDITIONAL INFORMATION.
- 5. ALL PLANTING AREAS SHALL BE MAINTAINED IN A WEED FREE CONDITION UNTIL PROJECT ACCEPTANCE.
- 6. PLANTS CAN BE INSPECTED AND REJECTED UPON DELIVERY.

WELO NOTES


- 1. A HORTICULTURAL SOIL ANALYST TEST SHALL BE CONDUCTED AT A MINIMUM OF (3) LOCATIONS THROUGHOUT THE PROJECT SITE, IN ADDITION TO AN ANALYSIS OF ANY TOP SOIL IMPORTED TO PROJECT PLANTING AREAS. CONTRACTOR TO FOLLOW AMENDMENT RECOMMENDATIONS FROM A QUALIFIED SOILS LABORATORY BASED ON TEST RESULTS.
- 2. SOIL AMENDMENT AND COMPOST TO BE ADDED TO PLANTING AREAS AT A RATE OF 4 CUBIC YARDS PER 1,000 SF. INCORPORATED TO A DEPTH OF SIX INCHES INTO THE SOIL.
- 3. A MINIMUM (3") LAYER OF MULCH SHALL BE APPLIED ON ALL EXPOSED SOIL SURFACES OF PLANTING AREAS
- EXCEPT IN TURF AREAS. REFER TO PLANTING PLAN FOR MULCH SPECIFICATION. 4. REFER TO CIVIL IMPROVEMENT PLANS FOR PLANTING AREA GRADING.

WATSONVILLE WATER EFFICIENT LANDSCAPE ORDINANCE.

- 5. A LANDSCAPE IRRIGATION AUDIT SHALL BE CONDUCTED BY EIEHR A LOCAL AGENCY LANDSCAPE IRRIGATION
- 6. LANDSCAPE CONTRACT TO INSTALL THIS IRRIGATION SYSTEM PER PLAN AND PER ALL REQUIREMENTS OF
- THE CITY OF WATSONVILLE WATER EFFICIENT LANDSCAPE ORDINANCE.

AUDITOR OR A THIRD PARTY LANDSCAPE IRRIGATION AUDITOR PER SECTION 492.12 OF THE CITY OF

I HAVE COMPLIED WITH THE CRITERIA OF THE ORDINANCE AND APPLIED THEM FOR THE EFFICIENT USE OF WATER IN THE IRRIGATION DESIGN PLAN.



RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

CONSULTANTS







PROJECT INFORMATION

GBxMB Watsonville

WATSONVILLE, CA 95076

© 2021 RYAN A+E, INC.

210020.00

DRAWN BY CHECKED BY JOB NO. DATE

ISSUE RECORD

2022-06-28


- 1			
	ISSUE #	DATE	DESCRIPTION
	1	07-27-21	DESIGN REVIEW SUBMITTAL
	2	09-30-21	DESIGN REVIEW RESUBMITTAL
	3	01-14-22	DESIGN REVIEW RESUBMITTAL
	4	04-15-22	DESIGN REVIEW RESUBMITTAL
	5	07-15-22	DESIGN REVIEW RESUBMITTAL

DESIGN REVIEW RESUBMITTAL

CONCEPTUAL LANDSCAPE PLAN

2022.06.28

Attachment 1 Page 41 of 44



WATER USE CALCULATION

MAWA = $(ETo) (0.62) [(0.45 \times LA) + (0.3 \times SLA)]$ $= (37.7) (0.62)[(0.45 \times 105,884) + (0.3 \times 0)]$ = (23.37)(47,647.80)=1,113,529.09

ETWU = (ETo) (0.62) [(PF X HA)/IE + SLA]

- = (37.7) (0.62) [44,802+0]
- = (23.37)(44,802)

= 1,047,022.74

MAWA = 1,113,529.09 GAL/YEAR ETWU = 1,047,022.74 GAL/YEAR

YDROZONE	PLANT WATER USE	IRRIGATION METHOD	PLANT FACTOR (PF)	HYDROZONE AREA (SQ. FT.) (HA)	PF X HA (SQ.FT)	IRRIGATION EFFICIENCY (IE)	PF X HA / (IE)
1	LOW	DRIP	0.3	33,757	10,127	0.81	12,502
2	LOW	BUBBLERS	0.5	1,700	850	0.81	1,049
3	LOW	DRIP	0.4	12,218	4,887	0.81	6,033
4	LOW	DRIP	0.3	28,141	8,442	0.81	10,422
5	LOW	BUBBLERS	0.5	850	425	0.81	525
6	LOW	DRIP	0.4	27,932	11,173	0.81	13,794
7	LOW	DRIP	0.3	1,286	386	0.81	477
TOTALS				105,884			44,802

IRRIGATION STATEMENT

CONTRACTOR TO PROVIDE AN AUTOMATIC IRRIGATION SYSTEM TO EFFECTIVELY WATER ALL PLANTS SHOWN ON LANDSCAPE PLAN. THE DESIGN OF THE IRRIGATION IMPROVEMENTS SHALL CONSIST OF DRIP IRRIGATION AND LOW FLOW ROTARY NOZZLES THAT WILL SUFFICIENTLY IRRIGATE THE PROPOSED PLANT MATERIAL IN COMPLIANCE WITH CALIFORNIA'S UPDATED MODEL WATER EFFICIENT LANDSCAPE ORDINANCE AB 1881 AND CITY OF WATSONVILLE REQUIREMENTS. HYDROZONES WILL BE DESIGNATED BASED ON SOLAR EXPOSURE, PLANT WATER REQUIREMENTS, SOIL TYPE, AND MICROCLIMATES.

HYDDOZONE I ECEND

HYDROZONE LEGEND				
HYDROZONE#	SYMBOL	DESCRIPTION	LANDSCAPE AREA	
HYDROZONE 1		NORTH EASTERN ASPECT - SHRUBS & GROUNDCOVERS	33,757	
HYDROZONE 2		NORTH EASTERN ASPECT - TREES	1,700	
HYDROZONE 3	ψ ψ ψ ψ ψ ψ ψ ψ ψ ψ ψ	NORTHERN ASPECT - BIORETENTION	12,218	
HYDROZONE 4		SOUTH WESTERN ASPECT - SHRUBS & GROUNDCOVERS	28,141	
HYDROZONE 5		SOUTH WESTERN ASPECT - TREES	850	
HYDROZONE 6	ψ ψ ψ ψ ψ ψ ψ ψ ψ ψ ψ	SOUTHERN ASPECT - BIORETENTION	27,932	
HYDROZONE 7		NATIVE RIPARIAN VEGETATION	1,286	



RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

CONSULTANTS







PROJECT INFORMATION

GBxMB Watsonville

WATSONVILLE, CA 95076

© 2021 RYAN A+E, INC.


DRAWN BY CHECKED BY JOB NO. DATE 210020.00 2022-06-28


	ISSUE RECORD			
ISSUE #	DATE	DESCRIPTION		
1	07-27-21	DESIGN REVIEW SUBMITTAL		
2	09-30-21	DESIGN REVIEW RESUBMITTA		
3	01-14-22	DESIGN REVIEW RESUBMITTA		
4	04-15-22	DESIGN REVIEW RESUBMITTA		
5	07-15-22	DESIGN REVIEW RESUBMITTA		

DESIGN REVIEW RESUBMITTAL 2022.06.28


CONCEPTUAL IRRIGATION PLAN

L-2.0






G DRIP ZONE REMOTE CONTROL VALVE KIT SCALE: 1/2" = 1'-0"



- CENTER VALVE BOX OVER REMOTE CONTROL VALVE OR GATE VALVE TO FACILITATE SERVICING VALVE.
 SET BOXES 1/2" ABOVE FINISH GRADE IN LAWN AREAS AND 1-1/2" ABOVE FINISH GRADE IN SHRUB AREAS.
- 3. SET BOXES PARALLEL TO EACH OTHER AND PERPENDICULAR TO EDGE OF WALL.
- 4. AVOID HEAVILY COMPACTING SOIL AROUND VALVE BOXES TO PREVENT COLLAPSE AND DEFORMATION OF VALVE BOX SIDES.
- 5. INSTALL EXTENSION BY VALVE BOX MANUFACTURER AS REQUIRED TO COMPLETELY ENCLOSE ASSEMBLY FOR EASY ACCESS. 6. VALVE BOXES TO BE CARSON MODEL 1419 BOLT DOWN FOR REMOTE CONTROL VALVES AND CARSON MODEL 910 FOR ROUND
- BOXES OR APPROVED EQUAL. 7. LOCATE VALVES IN SHRUB AREAS, NOT LAWN.







A.C. PAVING REPLACED IN KIND AND MADE ----


2. TAPE AND BUNDLE 24 V. CONDUCTORS AT 10' INTERVALS. DO NOT TAPE IN SLEEVES. 3. "SNAKE" WIRE AND PIPING SIDE TO SIDE IN TRENCH TO ALLOW FOR EARTH

- EXPANSION/CONTRACTION.
- 4. PIPING AND TRENCHING UNDER INCOMING PAVING SHALL BE BACKFILLED WITH CLEAN NATIVE SOIL AND SHALL BE COMPACTED TO 90% RC UNLESS NOTED OTHERWISE. ALL IRRIGATION
- PIPING UNDER ANY PAVING SHALL HAVE A MINIMUM OF 24 INCHES OF COVER. IN PLANTING AREAS, COMPACT TRENCH TO 85% RC UNLESS NOTED OTHERWISE.
- 5. WIRES TO BE INSTALLED IN CONDUIT.






















TREE BUBBLER

REMOTE CONTROL VALVE

BALL VALVE
SCALE: N.T.S.

RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

OWNER

CONSULTANTS







PROJECT INFORMATION

GBxMB Watsonville

WATSONVILLE, CA 95076

© 2021 RYAN A+E, INC.


DRAWN BY CHECKED BY CH JOB NO. DATE 210020.00 2022-06-28

ISSUE RECORD			
ISSUE #	DATE	DESCRIPTION	
1	07-27-21	DESIGN REVIEW SUBMITTAL	
2	09-30-21	DESIGN REVIEW RESUBMITTA	
3	01-14-22	DESIGN REVIEW RESUBMITTA	
4	04-15-22	DESIGN REVIEW RESUBMITTA	
5	07-15-22	DESIGN REVIEW RESUBMITTA	


DESIGN REVIEW RESUBMITTAL 2022.06.28

CONCEPTUAL LANDSCAPE DETAILS


L-3.0




SHRUB PLANTING




GROUNDCOVER AND SHRUB SPACING SCALE: N.T.S.






TYPICAL DRIP TUBING LAYOUT



B PEDESTAL CONTROLLER



TREE PLANTING

RYAN A+E, INC. 4275 Executive Square, Suite 370 La Jolla, CA 92037 858-812-7910 tel 858-812-7930 fax

WWW.RYANCOMPANIES.COM

OWNER

CONSULTANTS







PROJECT INFORMATION

GBxMB Watsonville

WATSONVILLE, CA 95076

© 2021 RYAN A+E, INC.

DRAWN BY CHECKED BY DATE JOB NO. 210020.00 2022-06-28

ISSUE RECORD SSUE # DATE DESCRIPTION 1 07-27-21 DESIGN REVIEW SUBMITTAL 2 09-30-21 DESIGN REVIEW RESUBMITTAL 3 01-14-22 DESIGN REVIEW RESUBMITTAL 4 04-15-22 DESIGN REVIEW RESUBMITTAL

5 07-15-22 DESIGN REVIEW RESUBMITTAL

DESIGN REVIEW RESUBMITTAL 2022.06.28

CONCEPTUAL LANDSCAPE DETAILS

L-3.1